

YUBA COUNTY ENVIRONMENTAL HEALTH DEPARTMENT

938 14TH STREET
MARYSVILLE, CA 95901
(530) 741-6251FEE: 240 PAID: 9-18-0213309

RECEIPT NO.

44 340 048

ASSESSOR'S PARCEL NO.

51630

APPLICATION FOR PERMIT TO CONSTRUCT, REPAIR, INACTIVATE, OR DESTROY A WELL

JOB LOCATION 7607 White Oak Lane NEAREST CROSS STREET Morning Dove
OWNER OF RECORD Gregg Mr. Lusher - & Nancy Bousall PHONE 42003
MAILING ADDRESS 4817 Sweet Grass Ln 2931 Texas Hill Rd Placerville, CA 95667-9594
DRILLING CONTRACTOR DAVID and Son Drilling LICENSE # 425609
MAILING ADDRESS P.O. Box 1029, Oroville 95966 PHONE 589-3914

PERMITTED ACTIVITY

☒ CONSTRUCT NEW WELL ☐ INSTALL NEW PUMP ☐ OTHER (STATE) _____
☐ DEEPEN WELL ☐ REPAIR PUMP ☐ TEST HOLE W/DESTRUCTION
☐ REPAIR WELL ☐ DESTROY WELL ☐ INACTIVATE WELL

COMMENTS: _____

INTENDED USE

☒ DOMESTIC/PRIVATE
☐ PUBLIC WATER SUPPLY (\$50.00 PLAN REVIEW)
☐ IRRIGATION
☐ INDUSTRIAL
☐ MONITOR
☐ OTHER (STATE) _____

TYPE OF WELL

☐ CABLE TOOL
☒ ROTARY
☐ OTHER (STATE) _____

CONSTRUCTION SPECIFICATIONS

ANNULAR SPACE: DIAM. 10 1/2 DEPTH OF SEAL 20 min
MATERIAL USED: PUC GRAVEL PACK ☐ YES ☒ NO
CASING: DIAM. 6" DEPTH 20 min
IF STEEL, GAUGE _____ OR THICKNESS _____
IF PLASTIC, TYPE F480 125 PSI (MUST MEET ASTM F-480)
IF CONDUCTOR, DIAM. _____ DEPTH _____

WELL LOCATED WITHIN AN EXISTING PUBLIC WATER SYSTEM BOUNDARY: ☒ YES ☒ NO NAME: irrigation only

COMMENTS: _____

WELL DESTRUCTION

DIAMETER _____ DEPTH _____ MATERIAL USED _____

- I will comply with all codes, rules and regulations of the State of California and County of Yuba pertaining to or regulating well construction.
 - I will call for a grout/destruction inspection at least 24 hours prior to pouring.
 - I will submit a water well driller's report to the Environmental Health Department within 15 days of well completion.
 - I will obtain final approval before placing well in service.
 - All materials used shall meet manufacturer's specifications.
- SIGNATURE OF DRILLING CONTRACTOR David R. Maerch DATE 9-16-2002

DATE OF WORK

START 9-25-2002

COMPLETION _____

WORKMAN'S COMPENSATION DECLARATION ON FILE? ☒ YES ☐ NO

OFFICIAL USE ONLY

LICENSE COPY ON FILE? ☒ YES ☐ NO

INSPECTION WAIVER _____

GROUT _____

SITE SURVEY _____

SEAL _____

LOG REC _____

YIELD _____

WATER SAMPLE _____

SANITARY SURVEY _____

REMARKS:

Maintain 100' setback
from existing or proposed
leach lines + 50' setback
from proposed septic tanks.


ISSUED [Signature]DATE 9/19/02FINAL APPROVAL N. BelovaDATE 02/03/03

PERMIT EXPIRES 1 YEAR FROM DATE OF ISSUE

WHITE - OFFICE CANARY - CONTRACTOR PINK - OWNER

White Oak Parcel
APN 44-34-48
Browns Valley

SCALE - 1/8" = 1 FT.



YUBA COUNTY ENVIRONMENTAL HEALTH
Water Well Field Response Form

Type of Work		
Construction	☒	Destruction
		Other

Job Location: 7607 White Oak Lane
Owner/Developer: Lusher APN: 44-340-48
Permit No: 02-5163 D Date: 9/24/2002

Drilling Company: David + Son
Total depth (feet): still drilling
Prod. casing depth (ft): 36'
Type of casing: PVC
Diameter: 6"
Gauge (if steel): WMM
Perforation depth (ft): WMM
Perforation size: WMM

Drilling method: Air Rotary
Diameter of borehole: 10 5/8"
Conductor casing depth (feet): None
Type of conductor casing: None
Diameter: WMM
Gauge (if steel): WMM
Well screen (type & size): WMM
Gravel pack (size in inches): WMM
From: WMM to WMM

Type of rock strata: clay + broken rock
blue rock

From: 0 to 33
33 to 67
 to
 to
 to

Vegetation: Oak trees Surrounding land use: proposed residential
Potential sources of contamination: septic system Distance (ft): 200±

Annular seal depth (ft): 33 Sealant used: Holeplug + benseal

Destruction seal depth (ft): N/A Fill material: N/A

Quantity of sealant: HHH + 1/2 bag benseal Proportion mixed: Ø

Method of sealing: freefall

Comments:

Larkin E. Buid
INSPECTED BY

9/23/2002
DATE

QUADRUPLICATE
For Local Requirements

STATE OF CALIFORNIA
WELL COMPLETION REPORT

Refer to Instruction Pamphlet

No. **756386**

DWR USE ONLY -- DO NOT FILL IN

STATE WELL NO./STATION NO.

LATITUDE LONGITUDE

APN/TRS/OTHER

Page 1 of 1

Owner's Well No. none

Date Work Began 9/23/02, Ended 9/25/02

Local Permit Agency YCEH

Permit No. 13309 Permit Date 9/19/02

GEOLOGIC LOG

WELL OWNER

ORIENTATION (✓) ☒ VERTICAL ☐ HORIZONTAL ☐ ANGLE ☐ (SPECIFY)

Name Rodney & Richard Farley

DEPTH FROM SURFACE
Ft. to Ft.

DRILLING METHOD AIR PRECUSSION FLUID ☐

Mailing Address 2931 Texas Hill Road

City Placerville

CA 95667

CITY

STATE

ZIP

DESCRIPTION

Describe material, grain, size, color, etc.

WELL LOCATION

Address White Oak Lane

City Browns Valley CA 95918

County Yuba

APN Book 44 Page 34 Parcel 48

Township 17 N Range 6 E Section 28

Latitude

DEG. MIN. SEC.

DEG. MIN. SEC.

LOCATION SKETCH

NORTH

ACTIVITY (✓)

☒ NEW WELL

MODIFICATION/REPAIR

☐ Deepen

☐ Other (Specify)

☐ DESTROY (Describe Procedures and Materials Under "GEOLOGIC LOG")

PLANNED USES (✓)

WATER SUPPLY

☒ Domestic ☐ Public

☐ Irrigation ☐ Industrial

MONITORING ☐

TEST WELL ☐

CATHODIC PROTECTION ☐

HEAT EXCHANGE ☐

DIRECT PUSH ☐


INJECTION ☐

VAPOR EXTRACTION ☐

SPARGING ☐

REMEDICATION ☐

OTHER (SPECIFY) ☐



Illustrate or Describe Distance of Well from Roads, Buildings, Fences, Rivers, etc. and attach a map. Use additional paper if necessary. PLEASE BE ACCURATE & COMPLETE.

WATER LEVEL & YIELD OF COMPLETED WELL

DEPTH TO FIRST WATER 289 (Ft.) BELOW SURFACE

1

DEPTH OF STATIC WATER LEVEL 289 (Ft.) & DATE MEASURED 9/24/02

ESTIMATED YIELD 5 (GPM) & TEST TYPE AIR LIFT

TEST LENGTH 2 (Hrs.) TOTAL DRAWDOWN 2 (Ft.)

May not be representative of a well's long-term yield.

DEPTH FROM SURFACE
Ft. to Ft.

BORE-HOLE DIA.
(Inches)

TYPE (✓)
BLANK SCREEN CON- DUCTOR FILL PIPE

CASING (S)

MATERIAL / GRADE

INTERNAL DIAMETER
(Inches)

GAUGE OR WALL THICKNESS

SLOT SIZE IF ANY
(Inches)

DEPTH FROM SURFACE
Ft. to Ft.

ANNULAR MATERIAL

TYPE

CE- MENT (✓) BEN- TONITE (✓) FILL (✓)

FILTER PACK (TYPE/SIZE)

0	36	10	✓			f480	6	125 psi	
0	300	6				f480	4	125 psi	
300	320	6		✓		f480	4	125 psi	1/8x6x4
320	360	6		✓		f480	4	125 psi	
360	400	6		✓		f480	4	125 psi	1/8x6x4

0	33		✓			
---	----	--	---	--	--	--

ATTACHMENTS (✓)

- ☐ Geologic Log
- ☐ Well Construction Diagram
- ☐ Geophysical Log(s)
- ☐ Soil/Water Chemical Analysis
- ☐ Other

ATTACH ADDITIONAL INFORMATION, IF IT EXISTS.

CERTIFICATION STATEMENT

I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief.

NAME David & Son Drilling

(PERSON, FIRM, OR CORPORATION) (TYPED OR PRINTED)

P.O. Box 1029

ADDRESS

Oroville CITY

CA 95965 STATE ZIP

Signed

David R. Mauer

WELL DRILLER/AUTHORIZED REPRESENTATIVE

10/01/02

DATE SIGNED

425609

C-57 LICENSE NUMBER