

TO: Justin Bang Moore Chi Bang Moore		WORK PERFORMED AT: 11450 E. Hwy 20 Clear Lake Oaks, Ca
DATE 9-8-23	YOUR WORK ORDER NO.	OUR BID NO.

DESCRIPTION OF WORK PERFORMED

Performed Well Test and took water sample for testing @ Alpha Labs.
 At this time we feel this well is capable of (3.6 Gpm).
 Note: All results are subject to change depending on time of year and weather conditions.
 Buz

System is in good working order

Recommend a water softener or iron filter to clean up the water. Water is lightly discolored.
 3.6 is marginal and Recommend a Holding tank Be installed, w/ Booster system Ball Park Quote for Booster system & tank is (\$5-\$6000. +-)

*Needs pump for Pump Protection (\$580+-)

Paying w/

Well Test	\$450.00
Potability	\$65.00
Total	\$515.00

Email Labs to: Tiffany@Countryair.com

All Material is guaranteed to be as specified, and the above work was performed in accordance with the drawings and specifications provided for the above work and was completed in a substantial workmanlike manner for the agreed sum of _____ Dollars (\$_____).

This is a ☐ Partial ☐ Full invoice due and payable by: _____ Month _____ Day _____ Year
 in accordance with our ☐ Agreement ☐ Proposal No. _____ Dated _____ Month _____ Day _____ Year