Jims Appollo Septic, Inc.

PO Box 56
Poway, CA 92074

Date	Invoice #
8/7/2026	10090

Invoice & Certification Report

Job Address	Bill to
4057 Ladera Vista Road Fallbrook CA 92028	Tracy Parker 619.455.3053 traceyparker66@icloud.com

Next Service Date	Terms	Due Date	Tank Type	Compartments	Condition
2/2029	Due on receipt	8/7/2026			

Service	Description	Rate	Qty	Amount
Inspection	The water test FAILED due to water coming out of the ground of the first leach line. I recommend a licensed contractor to locate and fix the problem. The inspection on the tanks have PASSED and are in working order.	225.00		225.00
Septic Pump	Main House - Cement / 2 compartment / Fair condition Pumped septic tank	600.00		600.00
Septic Pump	Guest House - Cement / 2 compartment / Fair condition Pumped septic tank	600.00		600.00

We appreciate your reviews! Find us on YELP!

Payments/Credits	$0.00
Balance Due	$1,425.00

Contact us!
Text/Call 760-533-7691
Email Jimsappolloseptic@hotmail.com

The enclosed billing statement is now due and payble. If this is an escrow involved transaction and we are not paid 30days after escrow is closed the acting officer who ordered service is responsible for payment. A $25 fee will be charged for all bounced checks.

venmo

Zelle