Jims Appollo Septic, Inc.

PO Box 56
Poway, CA 92074

Date	Invoice #
9/23/2026	10090

Invoice & Certification Report

Job Address	Bill to
4057 Ladera Vista Road Fallbrook CA 92028	Tracy Parker 619.455.3053 traceyparker66@icloud.com

Next Service Date	Terms	Due Date	Tank Type	Compartments	Condition
2/2029	Due on receipt	9/23/2026			

Service	Description	Rate	Qty	Amount
Inspection	PASSED a 40 minute water test on leach area. OK. No visible signs of failure at this date. The inspection on the tank is done and it has passed the water test indicating that the leach area is in standard working condition.	225.00		225.00
Septic Pump	Main House - Cement / 2 compartment / Fair condition Pumped septic tank	600.00		600.00
Septic Pump	Guest House - Cement / 2 compartment / Fair condition Pumped septic tank	600.00		600.00
Repair	I located the leach field. I ran a 40 minute water test on the second leach line and the last leach line, they both have passed. I ran a new cross over from the first leach line to the second leach line and an additional crossover to the last leach line.	4,200.00		4,200.00

We appreciate your reviews! Find us on YELP!

Payments/Credits	-$1,425.00
Balance Due	$4,200.00

Contact us!
Text/Call 760-533-7691
Email Jimsappolloseptic@hotmail.com

The enclosed billing statement is now due and payble. If this is an escrow involved transaction and we are not paid 30days after escrow is closed the acting officer who ordered service is responsible for payment. A $25 fee will be charged for all bounced checks.

venmo

Zelle