A & L LABORATORY
A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Christopher Baillargeon
28 Kennebec Trail
Turner, ME 04282

Date Printed: 06/27/2025
Work Order #: 2506-06250
Client Job #:
Date Received: 06/26/2025
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

Nashoba Analytical:
Identified by MA in the Analyst Column
31A Willow Road, Ayer, MA 01432
www.nashobaanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- ND: Non-detect. Results reported as Non-Detect (ND) have been evaluated down to the concentration listed in the MDL column.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical: accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here: None
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: Data Qualifier (DQ) Flags: None

SAMPLE STATE SPECIFIC NOTES:

Additional Narrative or Comments: None

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003; Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507
Nashoba Analytical: Accreditations: Massachusetts M-MA1118

A & L LABORATORY
A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 06/27/2025
CLIENT NAME: Christopher Baillargeon
CLIENT ADDRESS: 28 Kennebec Trail, Turner, ME 04282
SAMPLE ID #: 2506-06250-001
SAMPLED BY: Matt Hunt
SAMPLE ADDRESS: Baillargeon, 28 Kennebec Trail, Turner ME 04282
MORE LOC INFO: Kitchen

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

DATE AND TIME COLLECTED: 06/26/2025 08:55AM
DATE AND TIME RECEIVED: 06/26/2025 09:27AM
ANALYSIS PACKAGE: A & L MPN ME
RECEIPT TEMPERATURE: 17° CELSIUS
CLIENT JOB #:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
Coliform MPN*	<1	MPN/100mL	✓		1	No Limit	SM 9223 B	JR ME	06/27/2025 09:25AM
E. coli MPN*	<1	MPN/100mL	✓		1	0	SM 9223 B	JR ME	06/27/2025 09:25AM

Total Coliform / E.coli Bacteria Preparation (Colilert® 18 Quanti-Tray®) 20th ED SM 9223 B JR ME 06/26/2025 12:00PM

A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210

Phone (207) 784-5354

website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 06/23/2025
CLIENT NAME: Christopher Baillargeon
CLIENT ADDRESS: 28 Kennebec Trail
Turner, ME 04282

SAMPLE ID #: 2506-04712-001
SAMPLED BY: Matt Hunt
SAMPLE ADDRESS: Baillargeon
28 Kennebec Trail
Turner ME 04282
MORE LOC INFO: Kitchen

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

DATE AND TIME COLLECTED: 06/19/2025 08:55AM
DATE AND TIME RECEIVED: 06/19/2025 09:20AM
ANALYSIS PACKAGE: A & L-IC-FHA/VA-S-ME
RECEIPT TEMPERATURE: 16° CELSIUS
CLIENT JOB #:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
Arsenic*	<0.001	mg/L	✓		0.001	0.010 mg/L	EPA 200.8	JP-NH	06/20/2025 06:05PM
Calcium	21.9	mg/L			0.1	No Limit	EPA 200.8	JP-NH	06/20/2025 06:05PM
Copper*	0.0330	mg/L	✓		0.001	1.3 mg/L	EPA 200.8	JP-NH	06/20/2025 06:05PM
Hardness (calc.)	65.4	mg CaCO3/L			0.25	No Limit	EPA 200.8	JP-NH	06/20/2025 06:05PM
Iron	<0.1	mg/L	✓		0.1	0.3 mg/L	EPA 200.8	JP-NH	06/20/2025 06:05PM
Lead*	<0.001	mg/L	✓		0.001	0.015 mg/L	EPA 200.8	JP-NH	06/20/2025 06:05PM
Magnesium	2.59	mg/L			0.1	No Limit	EPA 200.8	JP-NH	06/20/2025 06:05PM
Manganese*	0.0131	mg/L	✓		0.001	0.05 mg/L	EPA 200.8	JP-NH	06/20/2025 06:05PM
Sodium	19.7	mg/L			0.1	No limit	EPA 200.8	JP-NH	06/20/2025 06:05PM
Chloride*	48	mg/L	✓		2	250 mg/L	EPA 300.0	JR-ME	06/19/2025 12:28PM
Fluoride*	<0.2	mg/L	✓		0.2	4.0 mg/L	EPA 300.0	JR-ME	06/19/2025 12:28PM
Nitrate as N*	0.73	mg/L	✓	T	0.2	10 mg/L	EPA 300.0	JR-ME	06/19/2025 12:28PM
Nitrite as N*	<0.2	mg/L	✓	T	0.2	1 mg/L	EPA 300.0	JR-ME	06/19/2025 12:28PM
pH*	6.72	SU	✓	H	--	6.5 - 8.5 SU	SM 4500H+B	JR-ME	06/19/2025 01:48PM
Coliform Bacteria*	Present	P-A/100mL	⚠		Absent	No Limit	SM 9223 B	JR-ME	06/20/2025 08:30AM
E. coli Bacteria*	Absent	P-A/100mL	✓		Absent	Absent	SM 9223 B	JR-ME	06/20/2025 08:30AM
Total Coliform / E.coli Bacteria Preparation (Colilert®-18) 20th ED							SM 9223 B	JR-ME	06/19/2025 11:55AM