ClearWater Laboratory

The Premier Water Testing Lab in Maine

153 Main Street
Newport, ME 04953
(207) 368-5700
diane@clearwaterlab.com

Sample # 2025-10-269DW.1
Sample Loc. Kitchen Sink -
Client Barrows, Robert A.
5 Anthony Ln.
Danvers, MA 01923

Property Information 12 Hall Quarry Rd.
Mt. Desert, ME 04660

PWSID #
Date/Time Collected 10/30/2025 0730
Date/Time Received 10/30/2025 1320 @ 18.3° C
Date Reported 11/03/2025

Legend
Passes ✓
Fails EPA Primary ✖
Fails EPA Secondary ▽
Unsatisfactory ⊗

Sampler Name Robert A. Barrows

REPORT OF LABORATORY ANALYSIS

Total Coliform	<1	MPN	0/100 mL	✓	Colilert	10/30/2025	1445	CWL	aw
E. coli	<1	MPN	0/100 mL	✓	Colilert	10/30/2025	1445	CWL	aw
Nitrate-N*	<1.0	mg/L	10	✓	4500-N03	10/30/2025	1455	CWL	jp
Nitrite-N*	<0.1	mg/L	1.0	✓	4500-N02	10/30/2025	1525	CWL	jp
pH*	7.18	S.U.	6.5-8.5	✓	STM4500 H+,B	10/30/2025	1331	CWL	jp

Laboratory CWL/ClearWater Laboratory - EPA Lab ID # ME00030

The results in this report pertain to the submitted sample only. This report shall not be reproduced, except in full, without written permission from ClearWater Laboratory. This report may contain data that were produced by a subcontracted laboratory accredited for the testing performed. * Nitrate/Nitrite samples received above 6C do not meet the accredited test method requirements, and a 3rd party may choose not to accept these results as valid. * pH samples received past 15 minutes after sampling do not meet the accredited test method requirements, and are not considered valid for compliance reporting purposes.

Signature:

Andrew G. Wendell/Senior Chemist/QA-QC Officer

GRANITE STATE
ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

Laboratory Report

ClearWater Laboratory
153 Main St
Newport, ME 04953

Date Printed:	**11/03/2025**
Work Order #:	**2510-06669**
Client Job #:	
Date Received:	**10/31/2025**
Sample collected in:	**Maine**

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

Nashoba Analytical:
Identified by MA in the Analyst Column
31A Willow Road, Ayer, MA 01432
www.nashobaanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- ND: Non-detect. Results reported as Non-Detect (ND) have been evaluated down to the concentration listed in the MDL column.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. None
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: Data Qualifier (DQ) Flags: None

SAMPLE STATE SPECIFIC NOTES:

Additional Narrative or Comments: None

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Donald A. D'Anjou, Ph. D.
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507
Nashoba Analytical: Accreditations: Massachusetts M-MA1118

GRANITE STATE
ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone (800) 699-9920 | (603) 432-3044 website www.granitestateanalytical.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 11/03/2025
CLIENT NAME: ClearWater Laboratory
CLIENT ADDRESS: 153 Main St
Newport, ME 04953

SAMPLE ID #: 2510-06669-001
SAMPLED BY: Client-Customer
SAMPLE ADDRESS: 2025-10-269DW
12 Hall Quarry Rd
Mt. Desert ME

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

DATE AND TIME COLLECTED: 10/30/2025 07:30AM
DATE AND TIME RECEIVED: 10/31/2025 08:06AM
ANALYSIS PACKAGE: Clearwater-Set A
RECEIPT TEMPERATURE: 18.2° CELSIUS
CLIENT JOB #:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
Arsenic*	<0.001	mg/L	✓		0.001	0.010 mg/L	EPA 200.8	JP-NH	10/31/2025 09:50PM
Calcium	18.9	mg/L			0.1	No Limit	EPA 200.8	JP-NH	10/31/2025 09:50PM
Copper*	0.0073	mg/L	✓		0.001	1.3 mg/L	EPA 200.8	JP-NH	10/31/2025 09:50PM
Hardness (calc.)	55.3	mg CaCO3/L			0.25	No Limit	EPA 200.8	JP-NH	10/31/2025 09:50PM
Iron	<0.1	mg/L	✓		0.1	0.3 mg/L	EPA 200.8	JP-NH	10/31/2025 09:50PM
Magnesium	1.96	mg/L			0.1	No Limit	EPA 200.8	JP-NH	10/31/2025 09:50PM
Manganese*	<0.001	mg/L	✓		0.001	0.05 mg/L	EPA 200.8	JP-NH	10/31/2025 09:50PM
Chloride*	21	mg/L	✓		2	250 mg/L	EPA 300.0	ST-NH	11/01/2025 01:48AM

Donald A. D'Anjou, Ph. D.
Laboratory Director