A & L LABORATORY
A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.
155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Pillar to Post - Lewiston
57 Gina St
Lewiston, ME 04240

Date Printed:	**09/13/2021**
Work Order #:	**2109-01648**
Client Job #:	
Date Received:	**09/10/2021**
Sample collected in:	**Maine**

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. None
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: Data Qualifier (DQ) Flags: None

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4ºC for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.
- The State of Maine requires the reporting of radon test results in accordance with the Act (22 MSRA sec. 771 et seq.). The following for all tests completed by A & L will be reported to the state on a monthly basis: address of the structure tested, radon result, and whether or not there is a mitigation system in place. A + symbol indicates State of Maine Radon Registration.
- The Maximum Exposure Guideline(MEG) for water radon in Maine is 4,000pCi/L

Additional Narrative or Comments: None

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director

A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210

Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 09/13/2021
CLIENT NAME: Pillar to Post - Lewiston
CLIENT ADDRESS: 57 Gina St
Lewiston, ME 04240

SAMPLE ID #: 2109-01648-001
SAMPLED BY: Joshua Westphal
SAMPLE ADDRESS: Holt
161 Ridley Road
Litchfield ME 04350
MORE LOC INFO: Drilled Well

Legend
- Passes ✓
- Fails EPA Primary ⊗
- Fails EPA Secondary ▽
- Fails State Guideline ✕
- Attention ⚠

DATE AND TIME COLLECTED: 09/09/2021 04:00PM
DATE AND TIME RECEIVED: 09/10/2021 01:02PM
ANALYSIS PACKAGE: A & L Radon Water
RECEIPT TEMPERATURE: 24° CELSIUS
CLIENT JOB #:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
Radon+	284	pCi/L	✓		100	4000 pCi/L	SM 7500-RN B	TT-ME	09/10/2021 08:59PM

Rebecca L. Labranche
Laboratory Director