nelanalytical
an analytichem company

P.O. BOX 788
Waterville Maine, 04901-0788

227 China Road
Winslow Maine, 04901

Administrative Offices
Phone: 1-207-873-7711
Fax: 1-207-873-7022

Customer Service
Phone: 1-800-244-8378
Fax: 1-207-873-7022

Certificate of Analysis

Attention: Norlen's Water Treatment LLC
575 River Rd
Orrington, ME 04474

Lab ID Number: 302603737
P.O. Number: 302603737 Flynn
Date/Time Collected: 6/12/2026 13:48
Date/Time Received: 6/13/2026 10:00
Date Reported: 6/15/2026

Owner: Mary Flynn/Treated
Location 96 Pirates Cove Rd Stockton Springs ME
Sample Type: Potability

Legend
- Meets Acceptable EPA Limits
- See Notation
- Does Not Meet EPA Limits

Parameter:		Your Result:	EPA LIMIT:	Unit:	Method:	Preparation Date/Time	Analysis Date/Time:	Reporting Limit:
Chloride, Total	✓	9.9	250	mg/L	SM 4500Cl- E		6/13/2026 / 14:13	0.50
Fluoride	✓	0.62	4.0	mg/L	SM 4500F E		6/13/2026 / 13:43	0.20
Nitrite-Nitrogen, Total	✓	<0.20	1	mg/L	NECi Method 1.0		6/13/2026 / 12:41	0.20
Nitrate-Nitrogen, Total	✓	<0.50	10	mg/L	NECi Method 1.0		6/13/2026 / 12:50	0.50
Arsenic, Total	✓	<1.000	10.0	µg/L	EPA 200.8	6/13/2026 / 15:25	6/15/2026 / 10:59	1.000
Lead Total	✓	<1.000	15.0	µg/L	EPA 200.8	6/13/2026 / 15:25	6/15/2026 / 10:59	1.000
Uranium Total	✓	<1.000	30	µg/L	EPA 200.8	6/13/2026 / 15:25	6/15/2026 / 10:59	1.000
Copper Total	✓	<0.001	1.3	mg/L	EPA 200.8	6/13/2026 / 15:25	6/15/2026 / 10:59	0.001
Iron Total	✓	<0.050	0.3	mg/L	EPA 200.8	6/13/2026 / 15:25	6/15/2026 / 10:59	0.050
Manganese Total	✓	<0.001	.05	mg/L	EPA 200.8	6/13/2026 / 15:25	6/15/2026 / 10:59	0.001
Sodium Total	⚠	61.9		mg/L	EPA 200.8	6/13/2026 / 15:25	6/15/2026 / 11:44	0.005


A 1/5 dilution was performed in order to bring the concentration of Sodium Total into the calibration range. The reporting limit has been adjusted accordingly.

*This sample is at or above the MEG of 20 mg/L of Sodium established by the MECDC. Sodium is not listed as a primary nor secondary contaminant of concern by the USEPA. See Notation 1.

Hardness by calculation		<10		mg/L	SM 2340B	6/13/2026 / 15:25	6/15/2026 / 10:59	10
Calcium, Total		<1.000		mg/L	EPA 200.8	6/13/2026 / 15:25	6/15/2026 / 10:59	1.000
Magnesium, Total		<1.000		mg/L	EPA 200.8	6/13/2026 / 15:25	6/15/2026 / 10:59	1.000
pH Electrometric	✓	7.81	6.5 to 8.5	stu@25C	EPA 150.1		6/13/2026 / 12:59	2.0
Total Coliform Colilert24	✓	<1		MPN/100mL	SM9223B	6/13/2026 / 10:44	6/14/2026/ 10:46	1
E.Coli - Colilert Enumeration	✓	<1	1	MPN/100mL	SM9223B	6/13/2026 / 10:44	6/14/2026/ 10:46	1

Comments:

✓ For the above tests performed by NEL only, this water meets acceptable EPA Limits.





nelanalytical
an analytichem company

P.O. BOX 788
Waterville Maine, 04901-0788

227 China Road
Winslow Maine, 04901

Administrative Offices
Phone: 1-207-873-7711
Fax: 1-207-873-7022

Customer Service
Phone: 1-800-244-8378
Fax: 1-207-873-7022

Certificate of Analysis

The following Notations may be referenced above.

Notation 1: The Maximum Exposure Guideline (MEG) is a health-based guideline set by the Maine Center for Disease Control and Prevention (MECDC). MEGs are recommendations for concentrations of chemical contaminants for all drinking water systems below which there is minimal risk of a harmful health effect resulting from long-term ingestion of contaminated water. These recommendations can be found online at <http://www.maine.gov/dhhs/mecdc/environmental-health/eohp/wells/documents/megtable2016.pdf>. Please contact one of the State of Maine's Bureau of Health Toxicologists, toll free, at 1-866-292-3474 for more information.

Notation 2: The Maximum Contamination Level (MCL) is set by the United States Environmental Protection Agency (USEPA) through the National Primary Drinking Water Regulations and are legally enforceable drinking water standards that apply to all public water systems. These regulations can be found online at <http://water.epa.gov/drink/contaminants/index.cfm> or by calling the Safe Drinking Water Hotline at 1-800-426-4791. Contaminants at or above the MCL are considered to impart potential negative health effects.

Notation 3: The Secondary Maximum Contamination Level (SMCL) is set by the United States Environmental Protection Agency (USEPA) through the National Secondary Drinking Water Regulations and these contaminants are not considered to present a risk to human health at the SMCL. These regulations can be found online at <http://water.epa.gov/drink/contaminants/secondarystandards.cfm> or by calling the Safe Drinking Water Hotline at 1-800-426-4791. Contaminants at or above (or below, only for pH) the SMCL may cause aesthetic considerations, such as taste, color and/or odor.

Notation 4: According to the EPA revised total coliform rule (effective April 1st, 2016) total coliform bacteria are no longer considered a primary contaminant. Total coliform bacteria are still used as indicator organisms for the presence of pathogens. Their presence in drinking water may indicate there is a route for pathogens (certain bacteria, viruses or protozoa) to enter the drinking water. Even though there is no longer an EPA limit, the presence of total coliform bacteria in drinking water is a problem requiring further action and investigation. If your water has tested positive for total coliform bacteria it is important to examine your water system and take action to eliminate the total coliform bacteria when possible. Please see the well disinfection procedure for more information @ <https://www.nelabservices.com/PDF/Resources/Well-Disinfection-Instructions.pdf>.

This report shall not be reproduced, except in full, without written permission from NELAnalytical.

If you have any questions regarding your results please call 1-800-244-8378 ext 300

Authorized By

Megan Bushover, Laboratory Technical Director

6/15/2026

Review Date

Analytical results and reports are generated by NELAnalytical at the request of and for the exclusive use of the person or entity (client) named on this report. Results, reports, or copies of same will not be released by NELAnalytical to any third party without the prior express written consent from the client named in this report. This report applies only to those samples taken at the time, place, and location referenced by the client. This report makes no express or implied warranty or guarantee as to the sampling methodology used by the individual performing the sampling. The client is solely responsible for the use and interpretation of these results, NELAnalytical does not make express or implied warranties as to such use or interpretation. NELAnalytical is not able to make and does not make a determination as to the environmental soundness, safety or health of a property from only the samples sent to their laboratory for analysis. Unless otherwise specified by the Client, NELAnalytical reserves the right to dispose of all samples after the testing of such samples is sufficiently completed or after a thirty-day period, whichever period is greater. NELAnalytical's liability extends only to the cost of the testing.

Winslow lab is accredited by the State of Maine Department of Health and Human Services, Maine Center for Disease Control and Prevention (ME00009) and by the National Environmental Laboratory Accreditation Program (NELAP) through the State of New Hampshire Environmental Laboratory Accreditation Program (#2534). To see a current list of certifications see our website: www.nelabservices.com.

eurofins | Environment Testing

Eurofins Auburn
Laboratory Report

Norlens Water Treatment
Tom Damaso
575 River Road
Orrington, ME 04474

Job ID:	**295-9736-1**
Date Received:	**6/13/2026 5:30 AM**
Sample Collected In:	**Maine**
Job Desc:	**Flynn**

The analytical test results presented in this report meet all requirements of the associated regulatory program listed in the Certification Summary section, unless otherwise noted. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

Receipt
The sample was received on 6/13/2026 5:30 AM. Unless otherwise noted below, the sample arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 20.0°C.

Certification Summary
Certifications for this job are presented below. Note that not all certifications may be applicable to your report and certifications for subcontracted laboratories are available upon request. Analytes not considered to be certified under the certifications associated with this report will have an asterisk next to their names. Evidence of certification for laboratories within Eurofins Environmental Testing can be found on the following website: https://www.eurofinsus.com/environment-testing/resources/certifications/

Eurofins Auburn (AUB), 155 Center Street, Building C, Auburn, ME 04210
Maine, Lab ID: ME01076
Maine (Rad), Lab ID: SPC20, RSP50083

Action Limit Summary
Sample results for 295-9736-1 have been evaluated against the following action limits and/or Maximum Contaminant Levels:
- EPA Primary Limits: Maine EPA Primary DW MCL
- EPA Secondary Limits: Maine EPA Secondary DW MCL
- State Limits: 295 - Maine - Guidelines

Definitions regarding the evaluations presented within this report are presented below:
- EPA Primary Limits: Legally enforceable standards known to affect human health.
- EPA Secondary Limits: Non-enforceable standards that may cause cosmetic or aesthetic effects.
- Pass: Result is below the action limit and/or MCL.
- Fail: Result is above the action limit and/or MCL.
- Attention: Result indicates a potential pathway for contaminants to enter the system that warrants investigation.
- No Limit: No action limit or MCL is available.

Analysis Related Notes
DF: "Dilution factor" means the ratio of the volume of the final (dilution) solution to the volume of sample.
MDL: "Minimum Detection Limit" means the minimum result which can be reliably distinguished from a blank with predetermined confidence level.
ND: Non-detected at the reporting limit (or MDL or EDL if shown).
RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
Data qualifier flags provide additional information in regards to the receipt, analysis or quality control of a sample. If any such flags are associated with the results of this report, they will be listed below along with their definitions.

eurofins | Environment Testing

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

1 2 3

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

CLIENT SAMPLE ID: 96 Pirates Cove Road, Stockton Springs ME 04981
SAMPLE ID #: 295-9736-1
CLIENT JOB #:
OTHER SAMPLE INFO: Drilled Well
SAMPLED BY: Tyler
COLLECTION DATE/TIME: 06/12/26 13:45

Test Description (SM7500_Rn_B)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Radon	1113	pCi/L	✓		100	1	4000	HP - AUB		06/13/26 19:38

Job ID: 295-9736-1

Authorized By: Amber Cusson, Operations Manager
Phone: (207)784-5354

6/15/2026