



Town of Paradise
Community Development Department
Building Resiliency Center
6295 Skyway
Paradise, CA 95969
(530) 872-6291 x411

PrimaryContact: RAY VARLINSKY
LOVE MARIANNA R & VARLINSKY RAY
3691 HONEY RUN RD
PARADISE, CA 95969

Permit Number: OS23-04088
AP Number: 052-141-017-000
Property Address: 6268 SKYWAY
Occupancy Type: Commercial

Evaluation Date: 10/13/2023

Evaluator: MAUNY ROETHLER
DOBRICH SEPTIC SERVICE,
INC

Evaluation Results

Pump Only	No
Access Risers in Place	Yes
Sanitary Tee - Inlet	Yes
Scum Depth, Inlet Compartment	0 Inches
Sludge Depth, Inlet Compartment	8 Inches
Structural Tank Condition	Good
Liquid from Operating Level	Normal
Baffle Condition	Good
Tank Volume	1000 Gallons
Volume of Waste Pumped	0 Gallons
Riser Condition	Good
Sanitary Tee - Outlet	Yes
Scum Depth, Outlet Compartment	0 Inches
Sludge Depth, Outlet Compartment	6 Inches
Tank Material	Concrete
Septic Tank Pumping Required	No
Was Septic Tank Pumped	No
Depth to Septic Tank Access Lid - Inlet	16 Inches
Depth to Septic Tank Access Lid - Outlet	16 Inches
Effluent Pump	No
Effluent Line Diverter Valve	No
Well on Property	No
Common Area/Community Absorption Field	No
Absorption Field Type	Standard
Surfacing Effluent	No
Hydraulic Load Test	Yes
Hydraulic Load Test - Results	Marginal
Down Slope Seepage	No
Saturated Absorption Field	No
Graywater Discharge	No

Evaluator Comments

Tank looks good at this time.

HLT test filled the tank above the outlet tee and stabilized after 30 minutes.

Location Sketch