Building	Unit	Room	Category	Description	P	Violation Severity Level	Notes
	General Area	GARAGE	ILLEGAL CONSTRUCTION	ILLEGAL CONSTRUCTION		HIGH	Unapprove garage converted garage, obtain permits from LADBS , final sign off and New C of O
1212870	423 E 65TH ST	LIVING ROOM	MAINTENANCE	FLOOR COVERING		LOW	Replace or repair damage flooring
1212870	423 E 65TH ST	HALL BATH	PLUMBING	FIXTURE DEF/LEAK		LOW	Tub spikett not working
1212870	423 E 65TH ST	HALL	HEATING AND VENTILATION	HEATING APPLIANCE		MEDIUM	Heat unit not working parts missing
1212870	423 E 65TH ST	HALL BATH	HEATING AND VENTILATION	VENTILATION-BATHS		LOW	Not working don't turn on