



The Original DOBRICH & SONS SEPTIC SERVICE
P.O. BOX 1681 MAGALIA, CA. 95954

INVOICE

(530)-873-9901

JOB SITE: 1474 Country Oaks

CITY Paradise	DATE ORDERED 11/10/2025	SCHEDULE DATE 11/11/2025	PUMP DATE
------------------	----------------------------	-----------------------------	-----------

ORDERED BY:	REPORT TO:
Kristin Wilson Ford	
Re/Max of Chico	
530-519-7600	

ESCROW COMPANY :	OFFICER:	ESCROW#
------------------	----------	---------

SPECIAL NOTES:
 Septic inspection of a 1500 gallon concrete septic tank that's in fair condition. The septic tank is 018" deep with plastic risers. There was 0" of Scum and 7" of sludge in the inlet side of the tank. The inlet and the outlet tees are intact. The effluent in the septic tank is at normal operating level. **The hydraulic load test could not be completed at this time. This is a pump system and the pump is not working. The tank will need new risers and lids. The pump, floats and splice box will need to be replaced.**

ORDER	DONE	DESCRIPTION	PRICE
X	X	INSPECTION Pump system	\$250.00
		INLET REPAIR	
		OUTLET REPAIR	
		EXTRA LABOR	
		PUMP NEEDED	
		PUMP ORDERED	
		"Due in 5 days. 1.5% interest will be added for each week an invoice is late unless escrow is pending"	

***This hydraulic load test of the absorption field does not constitute a full hydraulic load test of the dispersal field. A full hydraulic load test can only be effectively done with more water and when the system has been in continual use.

SUBTOTAL	\$250.00
AMOUNT PAID	
AMOUNT OWED	
CHECK#	

***NOTE: IF YOU PAY WITH A CREDIT CARD OR DEBIT CARD:
 There will be a 4% mandatory processing charge added to the total of the Invoice.

WE ARE IN BUSINESS BECAUSE OF YOU

THANK YOU