

Cook Pump and Well Service  
 6446 Windmill Place  
 Paso Robles, CA 93466  
 805-400-0151  
[cookpumpandwell@gmail.com](mailto:cookpumpandwell@gmail.com)  
 LIC# 1140304

Date: 02/27/2026

**This is to certify that Cook Pump and Well Service conducted a well test at the property address stated:**  
3505 Landmark Place Paso Robles CA 93446

**The Test was Performed by** Jason Cook **on the date of** 02/14/2026

**Datum Point:** Top of Casing **Static Level:** 593'

**Pump Setting:** 640' **Well depth:** 662'

**Horsepower:** 1.5 **Flow Method:** Bucket and stop watch

**Length of Test:** 4 hr + 15 min record **Casing Size:** \_\_\_\_\_

**Well Location:** 3505 Landmark Place Paso Robles CA 93446

Time:	Flow Rate (gpm)	Water Level (ft)	Notes:
10:00 am	0	593	
10:05 am	5	N/A	
10:10 am	5	N/A	No Sand
10:15 am	5	N/A	
10:20 am	5	N/A	
10:25 am	5	N/A	
10:30 am	5	N/A	
11:00 am	5	N/A	
11:30 am	5	N/A	
12:00 pm	5	N/A	
12:30 pm	5	N/A	
1:00 pm	5	N/A	
1:30 pm	5	N/A	
2:00 pm	5	N/A	
2:05 pm	5	N/A	
2:10 pm	5	N/A	
2:15 pm	5	N/A	