

Well Test Report

Byron Grant
Newer well on Suey Creek rd (next to generator)
Santa Maria, Ca 93454

4/7/2022

Re: 4 Hr Well Test Newer well on Suey Creek rd (next to generator)

<u>Time</u>	<u>GPM</u>	<u>PWL</u>
10:00	20.2	37'
10:05	20.2	51'
10:30	20.2	78'
11:00	20.2	78'
11:30	20.2	78'
12:00	20.2	78'
12:30	20.2	78'
1:00	20.2	78'
1:30	20.2	78'
2:00	20.2	78'
Recovery		
2:01	0	78'
2:05	0	61'
2:10	0	40'

Static Water Level 37'


Old pump was set at 380'

Test was conducted using a water meter

Water Level with Electric Sounder (PWL = *pumping water level*)

Thank You For Allowing Me To Be Of Assistance To Your Water Needs

Wes Mello / Owner



Mello & Son's Pumps & Motors
2773 Southview Ave.
Arroyo Grande, CA 93420
Office (805) 481-1286
Cell (805) 886-8293

Abalone Coast Analytical, Inc

141 Suburban Road, Suite C-1 San Luis Obispo CA, 93401

Phone: 595-1080 Fax: 595-1075

ELAP #2661

Order #: 22-1721

Date/Time Rec'd: 4/7/22 1525

Mello & Son's

2773 Southview Ave

Arroyo Grande, CA 93420

Contact: Wes Mello

Phone: 805-481-1286

Sampler: Wes Mello

Project: Suey Creek Newer Well by Generator

Sample #	Sample Description	Date / Time	Analysis	Method	Result	Units	RL	Completed
-1	Suey Creek	4/7/22 1305	Total Coliform	SM 9223 B.	Absent	/100ml	1	04/08/22
	Newer Well		E-Coli	IDEXX	Absent	/100ml	1	04/08/22

This sample passes water quality standards for Total Coliform and E. Coli Bacteria

Report Completion date:

4/8/22

Reviewed:



Priyanka Singh, Technical Director

Definitions:

Absent = Less than 1 CFU/100mLs

Present = 1

CFU = Colony Forming Unit

RL = Reporting Limit

State of California CDPH ELAP 2661

Coliform are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of Fecal coliforms and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.



2773 Southview Ave
 Arroyo Grande, CA.93420
 805-481-1286 886-8293
 h2owes.com Lic#725485

Invoice

DATE	INVOICE #
4/11/2022	6504

BILL TO
Byron Grant 102 Bridge St Arroyo Grande, Ca 93420

WELL INFORMATION

LOCATION	TERMS	CONTACT
Suey Creek ...	Due on receipt	Byron

QTY	DESCRIPTION	PRICE EACH	AMOUNT
1	Try to conduct 4 hour well test on newer well (well that had generator next to it) on Suey Creek road. Pump pulls high amps. Bring pump rig out and pull well pump. Install test pump and Conduct 4 hour well test. Collect water sample and take to lab. Pull test pump. Leave all old equipment on job site. Sales Tax Santa Barbara	1,700.00	1,700.00
		7.75%	0.00

Thank you for your business.

Total \$1,700.00

Well Test Report

Byron Grant
7840 Cougar Ridge Rd
Santa Maria, Ca 93454

4/6/2022

Re: 4 Hr Well Test at 7840 Cougar Ridge Rd

<u>Time</u>	<u>GPM</u>	<u>PWL</u>
10:00	23.2	
10:05	23.2	59'
10:30	23.2	64'
11:00	23.2	71'
11:30	32.2	71'
12:00	23.2	71'
12:30	23.2	71'
1:00	23.2	71'
1:30	23.2	71'
2:00	23.2	71'
Recovery		
2:01	0	71'
2:05	0	59'

Static Water Level 59'

Test was conducted using a water meter

Water Level with Electric Sounder (PWL = *pumping water level*)

Thank You For Allowing Me To Be Of Assistance To Your Water Needs

Wes Mello / Owner



Mello & Son's Pumps & Motors
2773 Southview Ave.
Arroyo Grande, CA 93420
Office (805) 481-1286
Cell (805) 886-8293

Abalone Coast Analytical, Inc

141 Suburban Road, Suite C-1 San Luis Obispo CA, 93401

Phone: 595-1080 Fax: 595-1075

ELAP #2661

Order #: 22-1636

Date/Time Rec'd: 4/5/22 1404

Mello & Son's

2773 Southview Ave

Arroyo Grande, CA 93420

Contact: Wes Mello

Phone: 805-481-1286

Sampler: Wes Mello

Project: Suey Creek Rd

Sample #	Sample Description	Date / Time	Analysis	Method	Result	Units	RL	Completed
1	7110 Suey Creek	4/5/22 1330	Total Coliform	SM 9223 B	Absent	100ml	1	4/10/22
	7110 Suey Creek		E-coli	IDEXX	Absent	100ml	1	4/10/22
-2	7840 Suey Creek	4/5/22 1335	Total Coliform	SM 9223 B	Absent	100ml	1	04/06/22
	7840 Suey Creek		E-coli	IDEXX	Absent	100ml	1	04/06/22

Report Completion date: 4/6/22

Reviewed: 

Priyanka Singh, Technical Director

Definitions:

Absent = Less than 1 CFU/100mls

Present = 1

CFU = Colony Forming Unit

RL = Reporting Limit

State of California CDPH ELAP 2661

Coliform are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.



2773 Southview Ave
Arroyo Grande, CA.93420
805-481-1286 886-8293
h2owes.com Lic#725485

Invoice

DATE	INVOICE #
4/11/2022	6502

BILL TO
Byron Grant 102 Bridge St Arroyo Grande, Ca 93420

WELL INFORMATION

LOCATION	TERMS	CONTACT
7840 Cougar	Due on receipt	Byron

QTY	DESCRIPTION	PRICE EACH	AMOUNT
1	Conduct 4 hour well test at 7840 Cougar Ridge, in Santa Maria. Collect water sample and take to lab. Sales Tax Santa Barbara	900.00	900.00
		7.75%	0.00
Thank you for your business.		Total	\$900.00



RECORD OF SURVEY

BEING A PORTION OF SECTIONS 25 & 34 NORTH, RANGE 34 WEST, SECTIONS 30 & 31 NORTH, RANGE 33 WEST IN THE UNINCORPORATED TOWNSHIP OF SAN LUIS, DIXIE COUNTY, ARIZONA AS SHOWN ON RECORD OF SURVEY IN PAGE 90 RECORDS OF SAID COUNTY.

SURVEYORS' CERTIFICATE:

THIS MAP CORRECTLY REPRESENTS A SURVEY MADE BY ME OR UNDER MY DIRECTION IN CONFORMANCE WITH THE REQUIREMENTS OF THE LAND SURVEYING ACT, AT THE REQUEST OF JAMES MANLYN ON NOVEMBER 25, 1905.

MICHAEL K. WELCH

COUNTY SURVEYORS CERTIFICATE:

THIS MAP HAS BEEN EXAMINED FOR CONFORMANCE WITH THE REQUIREMENTS OF THE LAND SURVEYORS ACT THIS 17TH DAY OF MAY 1974

~~Geography~~ COUNTY SURVEYOR R.C.E. 75665
1019

COUNTY RECORDER'S CERTIFICATE:

FILED THIS 24TH DAY OF MAY 1974, AT 4:30 PM
BOOK 20 OF RECORDS OF SURVEYS AT PAGE 61
REQUEST OF MICHAEL K. WELCH.

William E. Zimarik

NOTE:

THE LINE BETWEEN "IT IS A TYPICAL WAY OF STRESSING" FROM A RESEARCHER IN THE FIELD OF PSYCHOLOGY TO "IT IS A TYPICAL WAY OF STRESSING" FROM A RESEARCHER IN THE FIELD OF PSYCHOLOGY IS NOT A LINE BETWEEN "IT IS A TYPICAL WAY OF STRESSING" FROM A RESEARCHER IN THE FIELD OF PSYCHOLOGY TO "IT IS A TYPICAL WAY OF STRESSING" FROM A RESEARCHER IN THE FIELD OF PSYCHOLOGY.

M. K. WELCH SURVEYS, INC.

506 EAST CHAPEL STREET
SANTA ANA, CALIFORNIA 92704
PHONE: 805-926-8873

RECORD OF SURVEY

BEING A PORTION OF SECTIONS 25 & 30 TOWNSHIP 12 NORTH, RANGE 34 WEST, SECTIONS 30 & 31 TOWNSHIP 12 NORTH, RANGE 33 WEST IN THE UNINCORPORATED TERRITORY OF SAN LUIS OBISPO COUNTY, STATE OF CALIFORNIA AS SHOWN ON RECORD OF SURVEY FILED IN BOOK 14 PAGE 90 RECORDS OF SAID COUNTY.

SURVEYOR'S CERTIFICATE:
THIS MAP CORRECTLY REPRESENTS A SURVEY MADE BY ME
FOR UNDER MY DIRECTION IN CONFORMANCE WITH THE
REQUIREMENTS OF THE LAND SURVEYING ACT, AND
REQUEST OF JAMES MANIENS ON 11/20/2015.

Michael K. Welch
MICHAEL K. WELCH 45 3885

COUNTY SURVEYORS' CERTIFICATE
THIS MAP HAS BEEN EXAMINED FOR CONFORMANCE WITH THE REQUIREMENTS OF THE LAID SURVEYORS ACT THIS 17TH OF May 1974.

J.C. [Signature] R.C.E. 1968-5
COUNTY SURVEYOR 10137

COUNTY RECORDER'S CERTIFICATE
 TITLED THIS 24TH DAY OF MAY 1974 AT 4:30 P.
 BOOK 20 OF RECORDS OF SURVEYS AT PAGE 61 AT THE
 REQUEST OF MICHAEL K. WELCH.

TILE NUMBER: 11A39 FEE: \$5.00
William E. Zimarik

NOTE:

PREPARED BY:
M. K. WELCH SURVEYS, INC.

506 EAST CHAPEL STREET
SANTA MARIA, CALIFORNIA 93454
PHONE: 805-976-0873

