



Town of Paradise
 Community Development Department
 Building Resiliency Center
 6295 Skyway
 Paradise, CA 95969
 (530) 872-6291 x411

PrimaryContact: SNEHAL PATEL
 637 CIRCLEWOOD DR
 PARADISE, CA 95969

Permit Number: OS23-02376
AP Number: 052-380-004-000
Property Address: 637 CIRCLEWOOD DR
Occupancy Type: Single Family

Evaluation Date: 06/30/2023

Evaluator:

Evaluation Results

Pump Only	No
Access Risers in Place	No
Sanitary Tee - Inlet	Yes
Structural Tank Condition	Poor (describe in comments)
Liquid from Operating Level	Low (enter how low in the next question)
Liquid from Operating Level Distance	48 Inches
Baffle Condition	Poor (describe in comments)
Tank Volume	1000 Gallons
Volume of Waste Pumped	0 Gallons
Sanitary Tee - Outlet	Yes
Tank Material	Concrete
Septic Tank Pumping Required	No
Was Septic Tank Pumped	No
Depth to Septic Tank Access Lid - Inlet	6 Inches
Depth to Septic Tank Access Lid - Outlet	6 Inches
Effluent Pump	No
Effluent Line Diverter Valve	No
Well on Property	No
Common Area/Community Absorption Field	No
Absorption Field Type	Standard
Surfacing Effluent	No
Hydraulic Load Test	Yes
Hydraulic Load Test - Results	Excellent
Down Slope Seepage	No
Saturated Absorption Field	No
Multiple Systems	No
Graywater Discharge	No

Evaluator Comments

Tank is empty, with a wooden baffle.

Absorption Trenches look good.

Location Sketch