

SLO PUMPS, LLC
4882 Santa Margarita Lake Road
Santa Margarita, CA 93453
(805) 459-9078 Matt's Cell
LICENSE #: C57-881710

CUSTOMER NAME:	Tyler Keith	DATE: 3.18.26
PHONE NUMBER:	602-321-4578	
ADDRESS:	520 Stanton St	
CITY & STATE:	Arroyo Grande, CA 93420	
LOCATION OF TEST:	520 Stanton St, Arroyo Grande, CA 93420	

TEST INFORMATION:

TIME	WATER LEVEL	DRAW DOWN	G.P.M.	COMMENTS
8:45 AM	313	0	23	Clear
9:00 AM	325	-12	23	Clear
9:15 AM	325.5	-12.5	23	Clear
9:30 AM	325.5	-12.5	23	Clear
9:45 AM	325.5	-12.5	23	Clear
10:00 AM	326	-13	23	Clear
10:15 AM	326	-13	23	Clear
10:30 AM	326	-13	23	Clear
10:45 AM	326	-13	23	Clear
11:00 AM	326	-13	23	Clear
11:15 AM	326	-13	23	Clear
11:30 AM	326	-13	23	Clear
11:45 AM	326	-13	23	Clear
12:00 PM	326	-13	23	Clear
12:15 PM	326	-13	23	Clear
12:30 PM	326	-13	23	Clear
12:45 PM	326	-13	23	Clear

WELL INFORMATION:

WELL SIZE:	6 Inch	WELL DEPTH:	424 Feet
TEST PUMP SIZE:	3 HP		
STATIC LEVEL:	313	PUMPING LEVEL:	Unknown
HOURS OF RUNNING:	4		
TEST STARTED:	8:45 AM	SHUT DOWN:	12:45 PM
GPS:	35.069205 -120.556385		
SPECIFIC CAPACITY:	N/A		
PUMPING RATE:	23 GPM		
ADDITIONAL INFORMATION:	Only able to get down to 424 feet. Unknown if that is the pump level or bottom of the well.		

CONTRACTORS SIGNATURE	Chad Mazzi	DATE: 3.18.26
-----------------------	------------	---------------