

2 inch ABS Sewer
Cleanout



Roosevelt St.
Sewer line is less than three feet deep where it leaves the property and heads under the sidewalk (marked out in green).

Sewer lateral is clay starting under sidewalk and has several root invasions.

Could not view all the way to the city - should think about installing epoxy liner in this clay lateral to rehabilitate at the start of the job



**PRIVATE
PROPERTY**
**NO
TRESPASSING**
**VIOLATORS
WILL BE
PROSECUTED**

2023

**PRIVATE
PROPERTY**
**NO
TRESPASSING**
**VIOLATORS
WILL BE
PROSECUTED**


28

29

2

23

Sewer runs east to west in a straight line, and is ABS plastic for 30 feet Before it reaches the sidewalk, it is only about 2 feet deep The whole way



Can't tell the size of pipe.
- strongly recommend
connecting at the clay at the
edge of the sidewalk, and
then cleaning, evaluating and
rehabilitating the root
invaded clay lateral before
final connection

