JIM'S PUMPS
P.O. Box 474
Upper Lake, CA 95485
Telephone 707-349-2277
Jose Fernandez Jr.
CA# 993066

WELL TEST REPORT

JOB David Hull SIZE TURBINE 5Hp test Pump
LOCATION 2053 Martin St. Lakeport Ca SETTING 185 ft
WELL DEPTH 240 ft CASING SIZE 5" STATIC LEVEL 43'½
DATE STARTED 12-13-21 DATE COMPLETED 12-13-21

DATE	TIME		OPERATOR	G.P.M.	DRAWDOWN	WATER COLOR
	A.M.	P.M.				
12-13-21	9:00		Ben	7.5	43½	Grey & sand
	9:15			7.5	48	Grey & Little Amt of Sand
	9:30		Opened Up	11.1	50	Grey & Course Sand
	9:45			11.1	50	Grey-No Sand
	10:00		Opened Up	15.8	50	Grey-No Sand
	10:30		Opened Up	21	63	Grey-Little Sand
	11:00			21	70	Grey-Little Amt of Sand
	11:15		Opened up	23.1	71	Grey-Little Amount of Sand
	11:30			23.1	73	Grey No Sand
	11:45		Opened Up	33	85	Grey No Sand
		12:00		33	91	Grey w/ Sand
		12:15		33	91	Grey w/ Sand
		12:20	Throttled Back-Sand	25	91	Grey w/ Sand
		12:30		25	77	Grey w/ Sand
		12:45	Opened Up	30	76	Cloudy No Sand
		1:00	Opened up	37	80	Cloudy No Sand
		1:15		37	91	Cloudy w/ Little Amt of Sand
		1:30	Opened Up	45	97	Cloudy & Sandy

COMMENTS: Continued On Next Page....

JIM'S PUMPS
P.O. Box 474
Upper Lake, CA 95485
Telephone 707-349-2277
Jose Fernandez Jr.
CA# 993066

WELL TEST REPORT

JOB _____ SIZE TURBINE _____

LOCATION _____ SETTING _____

WELL DEPTH _____ CASING SIZE _____ STATIC LEVEL _____

DATE STARTED _____ DATE COMPLETED _____

DATE	TIME		OPERATOR	G.P.M.	DRAWDOWN	WATER COLOR
	A.M.	P.M.				
12-13-21		1:45		45	107 ft	Cloudy/Sandy
		2:00	Throttled Back	37	108 ft	Cloudy Little Sand
		2:15		37	108 ft	Cloudy No Sand
		2:30		37	108 ft	Cloudy No Sand
		3:00		37	108 ft	Cloudy No Sand
			End Test			

COMMENTS: At this time we feel this well is capable of (37 gpm). Note All results are subject to change depending on time of year and weather conditions