



Town of Paradise
Community Development Department
Building Resiliency Center
6295 Skyway
Paradise, CA 95969
(530) 872-6291 x411

PrimaryContact: BIG FIVE ATTN: GLORIA SILVA
MISSION MILE LLC
C/O BIG 5 CORPORATION
2525 EL SEGUNDO BLVD
EL SEGUNDO, CA 90245

Permit Number: OS22-03150
AP Number: 053-021-081-000
Property Address: 7337 SKYWAY
Occupancy Type: Commercial

Evaluation Date: 09/09/2022

Evaluator: MAUNY ROETHLER
DOBRICH SEPTIC SERVICE,
INC

Evaluation Results

Pump Only	No
Access Risers in Place	Yes
Sanitary Tee - Inlet	Yes
Scum Depth, Inlet Compartment	0 Inches
Sludge Depth, Inlet Compartment	6 Inches
Structural Tank Condition	Good
Liquid from Operating Level	Normal
Baffle Condition	Good
Tank Volume	1500 Gallons
Riser Condition	Fair/Satisfactory (describe in comments)
Sanitary Tee - Outlet	Yes
Scum Depth, Outlet Compartment	0 Inches
Sludge Depth, Outlet Compartment	3 Inches
Tank Material	Concrete
Septic Tank Pumping Required	No
Was Septic Tank Pumped	No
Depth to Septic Tank Access Lid - Inlet	10 Inches
Depth to Septic Tank Access Lid - Outlet	10 Inches
Effluent Pump	No
Effluent Line Diverter Valve	No
Well on Property	No
Common Area/Community Absorption Field	No
Absorption Field Type	Standard
Surfacing Effluent	No
Hydraulic Load Test	Yes
Hydraulic Load Test - Results	Excellent
Down Slope Seepage	No
Saturated Absorption Field	No
Multiple Systems	No
Graywater Discharge	No

Evaluator Comments

The inlet riser is melted to the lid.

Location Sketch

