Permit # BLD 26- 155

Address 1532 E Old Badillo St

Date Issued 04/15/2026

POST CONSPICUOUSLY ON THE JOB

CITY OF COVINA

Inspection Job Card

125 E College St.,Covina, CA 91723

Office Hours: 7:00am-6:00pm, Monday -Thursday

To cancel an inspection call:

(626)384-5460

Scan the QR Code on the left to view the daily inspection list & common inspection questions.

Submit your request for inspection to BLDinspections@covinaca.gov

Inspection Code	Inspection Type	Date	Inspector
Building Inspections			
B105	BMP *(Best Mgmt Practice)*		
B110	Excavation/Bottom		
B115	Drainage/Cultec-LID		
B200	Rough Grading		
B130	Setbacks		
B140	Foundation-Slab		
B150	Rebar/Anchors/HD		
B190	Floor Joist/Insulation		
B195	Floor Sheath 1st/ 2nd		
B350	Exterior Shear		
B355	Interior Shear		
B250	Rough Framing		
B400	Roof Sheathing/Tear-off		
B360	Exterior Lath		
B370	Insulation		
B395	Interior Lath	5-14-26	
B390	Drywall Nailing		
B365	Scratch Coat		
B310	T-Bar Ceiling		
B300	Pre-Grout Lift		
B485	Flat Work		
B320	Misc.		
B930	Reports/Observations		
Electrical Inspections			
B135	Ufer Ground		
B155	UG Conduit		
B160	Underfloor Electrical		
B210	Rough Electrical/ Conduit		
B215	Above T-Bar		
B340	Smoke/Carbon Monoxide		
B460	Meter Release		
B330	Solar PV		
B335	Temp Power Pole		
B900	Reports/Commissioning		
Other Agency/Division Final Approvals			
B485	**Environmental ext 5480**		
B480	**Planning ext 5450**		
B490	**Engineering ext 5440**		
(626) 430-3050	**LA County Fire Final**		

Inspection Code	Inspection Type	Date	Inspector
Plumbing Inspections			
B405	Water Service		
B180	Ug/Uf Plumbing		
B230	Rough Plumbing	5-12-26	
B410	Utility Disconnect		
B420	Sewer/Septic Connect		
B430	Grease Interceptor		
B440	Rough Gas		
B450	Final Gas Test		
B315	Above T-Bar		
B380	Shower Pan/Hot Mop		
B240	Rough Fire Sprinkler		
B425	Roof Drains		
B920	Reports/Test		
Mechanical Inspections			
B160	Underfloor Mech		
B220	Rough Mech/Duct		
B255	Exhaust Vent		
B260	Hood/Shaft		
B265	Hood Wrap 1st / 2nd		
B415	Above T-Bar		
B445	Smoke/Fire Dampers		
B910	Reports/HERS-Balance		
Pool & Spa Inspections			
B120	Pre-Gunite Rebar		
B180	UG Rough Plumbing		
B185	UG Electric Conduit		
B270	Backwash P-Trap		
B440	Gas Pipe Test		
B280	Pre-Deck, & Equip Bond		
B290	Enclosures/Alarm		
Building Division Final Approvals			
B500	**Electrical Final**	10-19-26	
B510	**Mechanical Final**	10-19-26	
B520	**Plumbing Final**	10-19-26	
B530	**Building Final**	10-19-26	

►Building Final Signature is your Certificate of Occupancy for Single Family Homes◄

PARTIAL ROUGH ELEC. NEED TO INSTALL HARD WIRE SMOKE DETECTOR 5-12-26

NEW RETRO FIT WINDOWS 5-12-26