



The Original DOBRICH & SONS SEPTIC SERVICE

P.O. BOX 1681 MAGALIA, CA. 95954

(530)-873-9901

INVOICE

JOB SITE: 14249 Sherwood Circle			NEEDS WORK		
			YES	X	NO
CITY Magalia	DATE ORDERED 06/16/2026	SCHEDULE DATE 06/18/2026	INSPECTION COMPLETED 06/18/2026		
ORDERED BY:		BILL/REPORT TO:			
Larry Knifong		c/o Larry Knifong			
Debbie Finney		3200 Fawnridge Court			
		Paradise, CA. 95969			
ESCROW COMPANY:		OFFICER:	ES#		
SPECIAL NOTES: Inspection of a 1500 gallon fiberglass septic tank. The septic tank is 16" deep. The tank did have risers but are burned off. There is 0" of scum and 11" of sludge in the inlet side of the tank. The inlet and outlet tees are intact. The effluent in the tank is at normal operating level in the tank. The tank is in poor condition due to burn damage. The tank needs to be replaced. The absorption field took the water that was introduced at the time of the hydraulic load test. The septic tank did not need to be pumped. (NOTE) There is heavy brush over the absorption field that could cause issues in the future.)					
ORDER	DONE	DESCRIPTION			
X	X	INSPECTION		\$250.00	
		INLET REPAIR			
		OUTLET REPAIR			
		EXTRA CHARGE Used equipment for locating tank			
		PUMP NEEDED			
		PUMP ORDERED			
SUBTOTAL				\$250.00	
AMOUNT PAID					
AMOUNT OWED					
CHECK#					

WE ARE IN BUSINESS BECAUSE OF YOU

THANK YOU