

JIM'S PUMPS
P.O. Box 474
Upper Lake, CA 95485
Telephone 707-349-2277
Jose Fernandez Jr.
CA# 993066

WELL TEST REPORT

JOB Christy Burnis SIZE TURBINE 1 1/2 HP motor / pump unknown
LOCATION 3328 Ackley Rd SETTING unknown
WELL DEPTH unknown CASING SIZE 8" Metal STATIC LEVEL 20'
DATE STARTED 7-28-25 DATE COMPLETED 7-28-25

DATE	TIME		Ken / Ryan OPERATOR	G.P.M.	DRAWDOWN	WATER COLOR
	A.M.	P.M.				
7-28-25	8:45			30	29'	Clear
	9:00			30	29'	Light Brown
	9:15			30	29'	Clear
	9:30			30	29'	Clear
	9:45			30	29'	Clear
	10:15			30	29'	Clear
	10:45			30	29'	Clear
End test	11:15			30	29'	Clear
Recovery	11:45			30	29'	Clear
	12:15			30	20'	

COMMENTS:

At this time we feel this well is capable of (30gpm)
NOTE All Results are subject to change depending on
Time of year and weather conditions