



3rd Gen Pump & Well
PO Box 2144
Pismo Beach, CA 93448
(805) 904-8808
Lic#1078879

Well Test Report

Well Name / Number	Big Well
Testing Date	5/22/2025
Standing Water Level	73'
Pump Setting	184'

4 Hour Continuous Well Test

Time	GPM	PWL	
8:30 AM	260	73'	Start
9:00AM	256	76'	
9:30AM	252	81'	
10:00AM	250	87'	
10:30AM	248	92'	
11:00AM	246	97'	
11:30AM	244	104'	
12:00AM	240	107'	Shutdown
12:30AM	240	110'	

Comments :

**The pumping equipment appeared to be operating properly - no indications of impending failure.
Testing represents performance on day of testing - not a guarantee of future operation.