

**TOWN OF PARADISE
ONSITE WASTEWATER MANAGEMENT ZONE
5555 SKYWAY PARADISE CA**

Date of Issue: 5/16/2017

ONSITE WASTEWATER DISPOSAL SYSTEM OPERATING PERMIT

Owner: Noble David H & Candice D
6227 Himmel St
Paradise, CA 95969

Permit Number: OS17-02952
AP Number: 050-440-001-000
Property Address: 6227 HIMMEL ST
Expiration Date: 9/16/2021

Structure(s) served by this onsite wastewater disposal system: Three (3) Bedroom - Residential
Onsite wastewater disposal system daily design flow: 300 gallons per day.
Evaluation/Construction inspection was performed on: 9/16/2014

EXISTING SYSTEM COMPONENTS

Standard - - Residential

Tank Details

Installation Date	Material	Liquid Capacity	Type
07/18/1990	Concrete	1000 Gallons	Septic

Absorption Field

Installation Date	Total Length	Trench Width	Total Rock
07/18/1990	150 Feet	24 Inches	12 Inches

Operating Permit Notes: RES OP - 3BDRM

Evaluator/Inspector:
ERIC HEGENBART
HEGENBART SEPTIC TANK CLEANING
530 877 8261

Certificate/License Number:
S-109

Additional onsite wastewater disposal system evaluations are required if there are any changes in the onsite system operating parameters.

This permit is valid until 9/16/2021.

The owner is responsible for having an evaluation performed within three months before this date in order to have this operating permit renewed.

Date: 5/16/2017

Signature:



188 MEMORIAL WAY
CHICO, CALIFORNIA 95927
894-2727

6227 Himmel

BUTTE COUNTY DEPARTMENT OF PUBLIC HEALTH
DIVISION OF ENVIRONMENTAL HEALTH

SEPTIC TANK INSPECTION CERTIFICATE

The Septic Tank System was installed at 6227 Himmel

FOR 3 BR House

LEACHING FIELD

SEPTIC TANK

Length 12 ft.
Width 3 in.


Size 1000 Gallons

No. of Lines 22

Material Concrete

APN 050-440-001-000
SITE 6227 Himmel St
MAX # BDRMS 3
MAX SQ FT 2900

The above dimensions meet the minimum requirements of the Building Code, Article 19. Additional leachings will be required if experience shows it to be necessary.



Remarks:

Date 7-18-90
22-778A