

State of California
Well Completion Report
Form DWR 188 Submitted
WCR2026-006648

Owner's Well Number: Lot # 1

Date Work Began: 05/22/2026

Date Work Ended: 07/03/2026

Local Permit Agency: County of Riverside Department of Environmental Health

County: Riverside

Secondary Permit Agency:

Permit Number: WP: 1000884

Permit Date: 04/20/2026

Well Owner (must remain confidential pursuant to Water Code 13752)

Name: Nuevo Partners Mark Lundberg

Business Name: ---

Address: 19120 92nd Ave W

City: Edmonds State: Washington Zip: 98020

Planned Use and Activity

Activity: New Production or Monitoring Well

Planned Use: Water Supply

Water Supply: Irrigation - Agriculture

Well Location

Address: 0 Montgomery & Nuevo RD

City: Nuevo Zip: 92567

Latitude: 33 Deg. 48 Min. 19.836 Sec. N

Longitude: -117 Deg. 7 Min. 22.44 Sec. W

Dec. Lat. : 33.80551

Dec. Long. : -117.1229

Location Accuracy:

Horizontal Datum:

Location Method:

APN: 427120042

Township: 04S Range: 02W

Section: 19 BM: San Bernardino

Ground Surface Elevation:

Elevation Accuracy:

Elevation Method:

Vertical Datum:

Borehole Information

Orientation: Vertical # of casings (Specify): 2

Drilling Method: Downhole Rotary Drilling Fluid:
Hammer Air

Total Depth of Boring: 300 (feet)

Total Depth of Completed Well: 300 (feet)

Water Level and Yield of Completed Well

Depth to first water: 100 (feet below surface)

Depth to Static Water Level: 60 (feet)

Date Measured: 07/07/2026

Estimated Yield*: 25 (GPM) Test Type: Air Lift

Test Length*: 4.5 (hours) Total Drawdown:

*May not be representative of a well's long term yield.

Geologic Log - Lite

Depth from Surface (Feet to Feet)		Material Type	Material Color	Material Texture	Material Description
0	50	Sand	Gray	Hard	
50	300	Granite	Black & White	Fractured	

Casings										
Casing #	Depth from Surface (Feet to Feet)		Casing Type	Material	Casings Specifications	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0	20	Conductor or Fill Pipe	Low Carbon Steel	Grade: ASTM A36	0.188	8.626			Sanitary Seal
1	20	300	No casing installed	Other	Other					No Casing Installed
2	0	80	Blank	PVC	OD: 4.500 in. SDR: SCH 40 Thickness: 0.237 in.	0.237	4.5			Blank
2	80	160	Screen	PVC	OD: 4.500 in. SDR: SCH 40 Thickness: 0.237 in.	0.237	4.5	Milled Slots	0.04	Screen
2	160	220	Blank	PVC	OD: 4.500 in. SDR: SCH 40 Thickness: 0.237 in.	0.237	4.5			Blank
2	220	280	Screen	PVC	OD: 4.500 in. SDR: SCH 40 Thickness: 0.237 in.	0.237	4.5	Milled Slots	0.04	Screen
2	280	300	Blank	PVC	OD: 4.500 in. SDR: SCH 40 Thickness: 0.237 in.	0.237	4.5			Blank

Annular Material					
Depth from Surface (Feet to Feet)		Fill	Fill Type Details	Filter Pack Size	Description
0	20	Bentonite	Low Solids		Sanitary Seal
0	300	Other Fill	See description		Pea Gravel

Other Observations:

Borehole Specifications		
Depth from Surface (Feet to Feet)		Borehole Diameter (inches)
0	20	14.75
20	300	7.8

Certification Statement			
I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief.			
Name:		<u>SEBASTIAN VALENTE</u>	
		Person, Firm or Corporation	
<u>38210 EAST BENTON ROAD</u>		<u>HEMET</u>	<u>California</u>
			<u>92544</u>

Address	City	State	Zip
<u>electronic signature received</u>		<u>07/18/2026</u>	<u>1037949</u>
Signed:		Date Signed	License Number
C-57 Licensed Water Well Contractor			

DWR Use Only							
CSG #	State Well Number			Site Code	Local Well Number		
----	----	----	N	----	----	----	W
Latitude Deg/Min/Sec				Longitude Deg/Min/Sec			
APN: ---- Township: ---- Range: ---- Section: ---- Tract: ---- SEQ: ---- BM: ----							

Attachments
No Attachments