



The Original DOBRICH & SONS SEPTIC SERVICE

P.O. BOX 1681 MAGALIA, CA. 95954

(530)-873-9901

INVOICE

JOB Site: 2363 Josephs Court			NEEDS WORK	
			YES	NO
				X
CITY Paradise	DATE ORDERED 05/19/2022	SCHEDULE DATE 05/23/2022	INSPECTION 05/23/2022	
ORDERED BY:		REPORT TO:		
Spencer Keables		Same		
Coldwell Banker				
(530)-520-9371				
ESCROW COMPANY :		OFFICER:	ESCROW#	
SPECIAL NOTES: Inspection of a 1500 Gallon Traffic Rated Concrete Septic Tank. The Tank is 8" deep. The Septic Tank has Steel Traffic Rated Risers in good condition. The Inlet and Outlet Tees are intact. There is 0" of Scum and 10" of Sludge. The water level in the Tank is normal. The Tank is in good condition. The Hydraulic Load Test indicates the Absorption Field is working normally at this time. No Septic Pump was necessary.				
ORDER	DONE	DESCRIPTION	PRICE	
X	X	INSPECTION Brought Water In	\$125.00	
		INLET REPAIR		
		OUTLET REPAIR		
		EXTRA LABOR		
		PUMP NEEDED		
		PUMP ORDERED		

Matthew Moore

Sumalee Gellner

05-31-2022

SUBTOTAL

\$125.00

AMOUNT PAID

AMOUNT OWED


CHECK#

WE ARE IN BUSINESS BECAUSE OF YOU

THANK YOU

This Map is not drawn to Scale. This is being offered to express a general idea or layout, and not to be used for construction. It is intended for information and not accurate construction information.

Location Sketch



2363 Josephs Court, Paradise

This Septic Inspection was completed and prepared by

The Original Dobrich & Sons Septic Service

P.O. Box 1681

Magalia, CA. 95954

(530)-873-9901

shirldob@aol.com