

State of California
Well Completion Report
Form DWR 188 Submitted
WCR2026-006302

Owner's Well Number: Date Work Began: 06/30/2026 Date Work Ended: 07/01/2026
Local Permit Agency: San Luis Obispo County Environmental Health Services County: San Luis Obispo
Secondary Permit Agency: Permit Number: 2026-046 Permit Date: 06/18/2026

Well Owner (must remain confidential pursuant to Water Code 13752)	Planned Use and Activity
Name: <u>---</u> Business Name: <u>JERRY BRANDT LIVING TRUST</u> Address: <u>54920 HUNTINGTON ROAD</u> City: <u>BEND</u> State: <u>Oregon</u> Zip: <u>97707</u>	Activity: <u>New Production or Monitoring Well</u> Planned Use: <u>Water Supply</u> Water Supply: <u>Domestic</u>

Well Location		
Address: <u>WILLOW ROAD</u> City: <u>NIPOMO</u> Zip: <u></u>		APN: <u>091-204-055</u> Township: <u>11N</u> Range: <u>35W</u> Section: <u>10</u> BM: <u>San Bernardino</u> Ground Surface Elevation: Elevation Accuracy: Elevation Method: Vertical Datum:
Latitude: <u>35 Deg. 2 Min. 44.664 Sec. N</u> Dec. Lat. : <u>35.04574</u> Location Accuracy: Location Method:	Longitude: <u>-120 Deg. 32 Min. 48.516 Sec. W</u> Dec. Long. : <u>-120.54681</u> Horizontal Datum:	

Borehole Information	Water Level and Yield of Completed Well
Orientation: <u>Vertical</u> # of casings (Specify): <u>1</u> Drilling Method: <u>Direct Rotary</u> Drilling Fluid: <u>Bentonite</u> Total Depth of Boring: <u>560 (feet)</u> Total Depth of Completed Well: <u>560 (feet)</u>	Depth to first water: Depth to Static Water Level: <u>260.2 (feet)</u> Date Measured: <u>07/01/2026</u> Estimated Yield*: <u>60 (GPM)</u> Test Type: <u>Air Lift</u> Test Length*: <u>2 (hours)</u> Total Drawdown: *May not be representative of a well's long term yield.

Geologic Log - Free Form		
Depth from Surface (Feet to Feet)		Description
0	227	BROWN SAND
227	279	SAND & GRAVELS
279	286	BROWN CLAY
286	315	SAND & GRAVELS

Depth from Surface (Feet to Feet)		Description
315	332	BROWN CLAY
332	338	SAND & GRAVELS
338	343	BROWN CLAY
343	351	SAND & GRAVELS
351	363	BROWN CLAY
363	374	SAND & GRAVELS
374	386	BROWN CLAY
386	393	SAND & GRAVELS
393	407	BROWN CLAY
407	452	SAND & GRAVELS
452	506	BROWN CLAY & GRAVEL MIXED
506	546	SAND & GRAVELS
546	560	BROWN CLAY WITH GRAVELS

Casings										
Casing #	Depth from Surface (Feet to Feet)		Casing Type	Material	Casings Specifications	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0	260	Blank	PVC	OD: 5.563 in. Thickness: 0.375 in.	0.375	5.563			
1	260	560	Other	PVC	OD: 5.563 in. Thickness: 0.375 in.	0.375	5.563	Saw Cut	0.04	

Annular Material					
Depth from Surface (Feet to Feet)		Fill	Fill Type Details	Filter Pack Size	Description
0	50	Cement	Portland Cement/Neat Cement		
50	560	Filter Pack	8 x 16		

Other Observations:

Borehole Specifications		
Depth from Surface (Feet to Feet)		Borehole Diameter (inches)
0	560	10

Certification Statement			
I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief.			
Name:	<u>FILIPPONI-THOMPSON DRILLING INC</u>		
	Person, Firm or Corporation		
<u>P O BOX 845</u>	<u>ATASCADERO</u>	<u>California</u>	<u>93423</u>

Address	City	State	Zip
Signed: <u>electronic signature received</u>	<u>07/08/2026</u>	<u>432680</u>	
C-57 Licensed Water Well Contractor	Date Signed	License Number	

DWR Use Only							
CSG #		State Well Number		Site Code	Local Well Number		
----		----	----	N	W		
Latitude Deg/Min/Sec				Longitude Deg/Min/Sec			
APN: ---- Township: ---- Range: ---- Section: ---- Tract: ---- SEQ: ---- BM: ----							

Attachments
No Attachments