


Owner/Agent: Mike Gilliland
 Date of Inspection: 7/30/2026
 Address: 2431 Mariposa Avenue



SEPTIC TANK PUMPER’S INSPECTION REPORT (Page 1 of 5)

SEPTIC TANK INFORMATION & CONDITION



ACCESS HATCH/LID (We check the lids to make sure there are no major cracks and That it fits snug. There needs to be enough lids to access each compartment, and their construction need to be sound and meets code.)

Lid Construction & Quantity: (2) Concrete

RISERS (Risers are lid extensions and if they are at the surface this makes it easier to service and monitor the system. If they are present we will check them for safety and operation.

Lid Condition: (2) Good
 Risers: No

TANK (We check condition of tank, walls, floor, etc. to determine its construction is sound, meets code, and is free from defects. We then measure the septic to determine its size and gallons pumped. Tanks need to be pumped for two reasons: 1 To inspect the septic tank 2. When the scum and sludge thickness exceeds 25% of the tank's depth to insure proper bacterial action and to keep the system working efficiently. Tanks are measured to the best of our ability with a tape measure and can vary due to the limited access.)

Tank Construction: Concrete
 Tank Condition: **Good**

Inside Length: 10 ft	x Inside Width: 3 ft	x Depth of Effluent: 5 ft	x 7.48 = Gallons:	1200
				Crust Thickness: 6 in
				Sludge Thickness: 5 in
				Gallons Pumped: 0

**If the above "Percent of Solids" is greater than 40% this may indicate a lack of pumping and/or maintenance of the system, if there is a concern that solids may have filtered out to the leach field, we can do further investigation upon your request.*

SEPTIC TANK PUMPER REPORT (Page 2 of 5)

Address: 2431 Mariposa Avenue

Date of Inspection: 7/30/2026

SEPTIC TANK INFORMATION & CONDITION (continued)

OPERATION (We are looking for evidence of abnormal water levels. Level should be at the invert (bottom) of outlet sanitary tee. Water level higher than the outlet pipe or evidence of seepage into the soil through the lids of the tank may point to possible leach field problems. If the water level is low in the septic then it could be evidence of seam leaking septage out of the tank. We also check around the septic area, if known, to determine if there is any evidence of possible problems indicated by seepage in the soil, odor, or other. If available we will attempt to test the outgoing line with 100-150 gallons of water – all of the water should be accepted by this line.)

Water Level: **Empty**

Did Water Flow Back: **No**

Evidence of Surfacing: **No**

Gallons Used For

Operation Test: **150**

Result of Load Test: **Excellent – 100%**

BAFFLE (The baffle separates the solids in the first compartment and allows liquid into the second compartment. The baffles are checked for defects, that its construction is sound, and meets code.)

Baffle Construction &

Condition: **Concrete / Good**

INLET & OUTLET TEES (We check the inlet and outlet sanitary tees to make sure they are securely attached with approximately 12 to 18 inch drop lines on each, and that their construction is sound and meets code.)

Inlet Construction &

Condition: **4" Clay / Good**

EFFLUENT FILTER (If present, we will pull this filter, inspect it, and clean it of sludge buildup and reinstall. Not all septic have this filter, but if one is present it should be cleaned annually.)

Outlet Construction &

Condition: **4" Clay / Good**

Outlet Filter: **No**

OTHER (Some systems may require additional services like county required annual maintenance and 24hr monitoring)

County Maintenance

Required: **No**

RECOMMENDATIONS/CORRECTION/REMARKS

Passes Inspection. Everything is operating at this time.

Repair recommendations and associated costs are based on conditions observed during the inspection. Because portions of the system are underground and inaccessible without excavation, additional deficiencies may be discovered during the repair process. Should unforeseen conditions be encountered, recommendations and pricing may be adjusted accordingly

The average septic tank should be pumped every three to five years to insure proper bacterial action and to keep the system working efficiently. As you know, this maintenance is critical to the over-all performance of the sewage disposal system, neglecting to perform this maintenance can lead to premature backing up of your septic tank.

We also recommend water conservation should be enlisted for household water use to maximize the life expectancy of the absorption trenches. Each septic system has a certain capacity. When this capacity is reached or exceeded, there will likely be problems because the system won't take as much sewage as you want to discharge into it. When the onsite sewage treatment system reaches its daily capacity, be conservative with your use of water. Each gallon of water that flows into the drain must go through the septic tank and into the soil absorption unit. There may be other ways to conserve water that you can think of in your home. The main idea is to consider water as a valuable resource and not to waste it. Take care of any household leaks to avoid unnecessarily saturating the leach trenches.

Following a few simple rules like not using too much water and not depositing materials in the septic tank that bacteria can't decompose should help to make a septic system trouble free for many years. But don't forget the septic tank does need to be cleaned out when too many solids build up. Septic tanks need tender, loving care too!

On behalf of all of us, thank you for this opportunity to work with you.

Chico Septic
5050 Cohasset Rd. Suite 70, Chico, CA 95973

SEPTIC TANK PUMPER REPORT (Page 3 of 5)

SEPTIC TANK TIPS AND INFORMATION

- ✓ Do: Get general maintenance inspections and pumps every 2-5 years.
- ✓ Do: Properly dispose of food scraps and grease before washing the dishes.
- ✓ Do: Wash full loads of laundry evenly throughout the week.
- ✓ Do: Use normal amounts of household chemicals.
- ✓ Do: Know the location of your tank and drainfield before landscaping.
- ✗ Don't: Flush anything except the 3 Ps down the toilet (Pee Poop Paper).
- ✗ Don't: Use your garbage disposal; the garbage can lead to drain field clogs.
- ✗ Don't: Park or drive on your drain field.
- ✗ Don't: Plant trees or shrubs too close to your drain field or on top of your lids.
- ✗ Don't: Dump cleaning water for latex paint brushes/cans into the septic system.

Find us online!



www.chicoseptic.com



facebook.com/chicosepticservice



[@chicosepticservices](https://www.instagram.com/chicosepticservices)

WE DECLARE THAT THE INFORMATION HEREIN IS TRUE AND CORRECT TO THE BEST OF OUR KNOWLEDGE. Our assessment reflects the condition of the septic system only at the time of pumping on the date noted above. We cannot be held liable for any conditions that may arise after the inspection, including past or future issues related to weather, property vacancy at the time of inspection, changes in household size, or improper care and maintenance of the system.

These reports are considered public record and may be shared with out interested parties.

If the system passes inspection, satisfactory performance is expected at that time. However, as this is an existing and previously used septic system, no guarantee can be made regarding the duration of continued satisfactory operation

SEPTIC TANK PUMPER REPORT (Page 4 of 5)

Please call us at 530-343-6340 to set up your quarterly cleaning and effluent filter installation.



BASIC ANNUAL PLAN

2431 Mariposa Avenue

Address

7/29/2026

Date



7/29/2027

Valid Through

Plan will automatically renew unless canceled 30 days prior to Valid Through Date.

Septic Tank Pumper Report (Page 5 of 5)

Complete Septic & Sewer Service!

5050 Cohasset Road, Suite 70. Chico, CA 95973



2431 mariposa ave.

