

TRIPLICATE

Owner's Copy

Page 1 of 1

Owner's Well No. PAYTON

Date Work Began 3/15/04, Ended 3/22/04

Local Permit Agency COUNTY OF SAN LUIS OBISPO

Permit No. 2003-274 Permit Date 7/31/03

WELL COMPLETION REPORT

STATE OF CALIFORNIA
Refer to Instruction Pamphlet

DWR USE ONLY -- DO NOT FILL IN	
STATE WELL NO./STATION NO.	
LATITUDE	LONGITUDE
APN/TRS/OTHER	

GEOLOGIC LOG

ORIENTATION (✓) ☒ VERTICAL ☐ HORIZONTAL ☐ ANGLE (SPECIFY)		DRILLING METHOD <u>ROTARY</u> FLUID <u>MUD</u>
DEPTH FROM SURFACE Ft. to Ft.	DESCRIPTION Describe material, grain, size, color, etc.	
0	20	TAN ADOBE CLAY
20	30	CLEAR CLEAN SAND
30	70	TAN CLAY
70	125	CLEAR SAND
125	180	TAN CLAY W/SAND LAYERS
180	200	TAN GREEN CLAY
200	210	FINE GREY SAND
210	215	COARSE SAND
215	220	FINE GREY SAND
220	240	COARSE SAND
240	335	FINE AND COARSE SAND
335	360	GREY CLAY
360	370	GREEN CLAY
370	385	FINE GREY SAND
385	390	GREEN CLAY
390	400	FINE GREY SAND
400	450	GREEN CLAY
450	550	FINE GREY SAND
550	560	GREEN CLAY
560	565	DARK GREY SAND
565	585	DARK GREY CLAY
585	615	DARK GREY SAND
615	700	GREEN CLAY
700	750	DARK GREY SAND
750	755	DARK GREY SAND
755	760	DARK GREEN CLAY

TOTAL DEPTH OF BORING 760 (Feet)
TOTAL DEPTH OF COMPLETED WELL 760 (Feet)

WELL OWNER

Name CHAD PAYTON
Mailing Address 1352 NORTH HIGUERA ST #
SAN LUIS OBISPO CA 93401
CITY STATE ZIP

WELL LOCATION

Address ROLLING HILLS
City CRESTON CA 93446
County SAN LUIS OBISPO
APN Book 042 Page 281 Parcel 007
Township 27 S Range 14 E Section 22
Latitude

DEG. MIN. SEC.		DEG. MIN. SEC.	
LOCATION SKETCH		ACTIVITY (✓)	
		☒ NEW WELL	
		MODIFICATION/REPAIR ☐ Deepen ☐ Other (Specify)	
Illustrate or Describe Distance of Well from Roads, Buildings, Fences, Rivers, etc. and attach a map. Use additional paper if necessary. PLEASE BE ACCURATE & COMPLETE.		DESTROY (Describe Procedures and Materials Under "GEOLOGIC LOG")	
		PLANNED USES (✓) WATER SUPPLY ☒ Domestic ☐ Public ☐ Irrigation ☐ Industrial	
		MONITORING ☐	
		TEST WELL ☐	
		CATHODIC PROTECTION ☐	
		HEAT EXCHANGE ☐	
		DIRECT PUSH ☐	
		INJECTION ☐	
		VAPOR EXTRACTION ☐	
		SPARGING ☐	
		REMEDICATION ☐	
		OTHER (SPECIFY) ☐	

WATER LEVEL & YIELD OF COMPLETED WELL

DEPTH TO FIRST WATER 560 (Ft.) BELOW SURFACE
DEPTH OF STATIC WATER LEVEL 487 (Ft.) & DATE MEASURED 3/22/04
ESTIMATED YIELD * 25-30 (GPM) & TEST TYPE AIR LIFT
TEST LENGTH 4 (Hrs.) TOTAL DRAWDOWN (Ft.)

May not be representative of a well's long-term yield.

DEPTH FROM SURFACE Ft. to Ft.	BORE-HOLE DIA. (Inches)	CASING (S)					
		TYPE (✓)	MATERIAL / GRADE	INTERNAL DIAMETER (Inches)	GAUGE OR WALL THICKNESS	SLOT SIZE IF ANY (Inches)	
0	520	10	✓	PVC/STEEL	5	F-480	
520	760	10	✓	PVC/STEEL	5	F-480	.032

DEPTH FROM SURFACE Ft. to Ft.	ANNULAR MATERIAL			
	CE- MENT (✓)	BEN- TONITE (✓)	FILL (✓)	FILTER PACK (TYPE/SIZE)
0	50	✓		
50	760		✓	GRAVEL

ATTACHMENTS (✓)

- ☐ Geologic Log
- ☐ Well Construction Diagram
- ☐ Geophysical Log(s)
- ☐ Soil/Water Chemical Analysis
- ☐ Other

ATTACH ADDITIONAL INFORMATION, IF IT EXISTS.

CERTIFICATION STATEMENT

I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief.

NAME Bailey Drilling & Pump

(PERSON, FIRM, OR CORPORATION) (TYPED OR PRINTED)

3450 South El Pomar Road

ADDRESS

Signed [Signature]

WELL DRILLER/AUTHORIZED REPRESENTATIVE

Templeton

CITY

CA

STATE

93465

ZIP

05/14/04

DATE SIGNED

804243

C-57 LICENSE NUMBER

BAILEY DRILLING & PUMP

3450 South El Pomar Road
 Templeton, CA 93465
 (805) 434-1944 License #804243

PUMP TEST REPORT**Owner:** Payton**Pump Set:** 714'**Well #:** 1**Address:** Rolling Hills**Pump Size:** 3 hp**Well Depth:** 760'

Creston

Testing Method: Open Discharge**Standing Level Before Test:****APN/Location:**

TIME	PUMPING LEVEL	GPM	WATER CONDITION
9:00	487	10	Clear
9:10	488	10	Foggy
9:20	489	10	Foggy
9:30	489.5	10	Foggy
9:45	490	10	Clearing
10:00	490	10	Clearing
10:15	490	10	Clear
10:30	490	10	Clear
11:00	490	10	Clear
11:30	490	10	Clear
12:00	490	10	Clear
12:30	490	10	Clear
1:00	490	10	Clear
1:30	490	10	Clear
2:00	490	10	Clear
2:30	490	10	Clear
3:00	490	10	Clear

Comments: Collected water samples for arsenic – sulfur – salt – potability.

Nothing detected from lab.

Well Produced 10 GPM for 6 Hours on 04-19-04

Test Ran By: Ray Shoemaker