



**The Original DOBRICH & SONS SEPTIC SERVICE**  
**P.O. BOX 1681 MAGALIA, CA. 95954**

**INVOICE**

**(530)-873-9901**

**JOB SITE: 5968 Maxwell Drive**

|                         |                                  |                                   |                  |
|-------------------------|----------------------------------|-----------------------------------|------------------|
| <b>CITY</b><br>Paradise | <b>DATE ORDERED</b><br>6/23/2025 | <b>SCHEDULE DATE</b><br>6/25/2025 | <b>PUMP DATE</b> |
| <b>ORDERED BY:</b>      |                                  | <b>REPORT TO:</b>                 |                  |
| Rex Arashi              |                                  |                                   |                  |
| rharashi@gmail.com      |                                  |                                   |                  |
| 530-838-5358            |                                  |                                   |                  |
|                         |                                  |                                   |                  |
| <b>ESCROW COMPANY :</b> |                                  | <b>OFFICER:</b>                   | <b>ESCROW#</b>   |

**SPECIAL NOTES:**

Septic inspection of a 1500 gallon concrete septic tank that's in good condition. The septic tank is 14" deep. There was 0" of Scum and 4" of sludge in the inlet side of the tank. The inlet and the outlet tees are intact. The effluent in the septic tank is at normal operating level. The absorption field is operating as it should. The tank does not need to be pumped.

| ORDER | DONE | DESCRIPTION                                                                                            | PRICE    |
|-------|------|--------------------------------------------------------------------------------------------------------|----------|
| X     | X    | INSPECTION                                                                                             | \$200.00 |
|       |      | INLET REPAIR                                                                                           |          |
|       |      | OUTLET REPAIR                                                                                          |          |
|       |      | EXTRA LABOR                                                                                            |          |
|       |      | PUMP NEEDED                                                                                            |          |
|       |      | PUMP ORDERED                                                                                           |          |
|       |      |                                                                                                        |          |
|       |      | "Due in 5 days. 1.5% interest will be added for each week an invoice is late unless escrow is pending" |          |

\*\*\*This hydraulic load test of the absorption field does not constitute a full hydraulic load test of the dispersal field. A full hydraulic load test can only be effectively done with more water and when the system has been in continual use.

**SUBTOTAL**

**\$200.00**

**AMOUNT PAID**

**AMOUNT OWED**

**CHECK#**

\*\*\*NOTE: IF YOU PAY WITH A CREDIT CARD OR DEBIT CARD:

There will be a 4% mandatory processing charge added to the total of the Invoice.

**WE ARE IN BUSINESS BECAUSE OF YOU**

**THANK YOU**