



FARM SUPPLY COMPANY-SL
224 Tank Farm Road
San Luis Obispo CA 93401

PAGE NO 1

PHONE: (805) 543-3751

REMITTANCE ADDRESS: 224 TANK FARM ROAD
SAN LUIS OBISPO CA 93401

SOLD TO: RICHARD BURKETT *R/O*
LORRAINE BURKETT
1415 SAN MARCOS RD
PASO ROBLES CA 93446
213-810-3907

CUST NO: 82123
TERMS: CASH/CHECK/BANKC

DATE: 7/22/26 TIME: 11:18
CLERK: BMC TERMINAL: 563
SALESPERSON: 01 PUMP DEPT
TAX: SL1 SL STORE TAX

SHIP TO: [REDACTED]

REFERENCE: 1415 SAN MARCOS RD
JOB NO: 000
DEL. DATE: 7/22/26
DUE DATE: 7/23/26

REWARD NO: 0000082123
ORDER: 335361

INVOICE: D35390

LINE	QTY	UM	SKU	DESCRIPTION	UNITS	SUGG	PRICE/	PER	EXTENSION	
1				7/21/26						
2										
3				CUSTOMER RICHARD 213.810.3907						
4				BILLIE JO 805.878.5582						
5										
6				4 HOUR WELL TEST AND BACERTIA						
7				SAMPLE						
8										
9				TECH TRAVIS						
10										
11				TECH ARRIVED TO PERFORM WELL						
12				TEST AND COLLECT SAMPLE. MET						
13				CUSTOMER AND SHOWN TO WELL.						
14				BEGAN HOOKING UP METER TO WELL						
15				AND MEASURED - SWL @ 84'. BEGAN						
16				TEST AND PUMP WAS DOING 50 GPM						
17				BUT SWL WAS DROPPING. SLOWED						
18				PUMP DOWN TO 35 GPM AND SWL						
19				STABALIZED @ 191'. COLLECTED						
20				SAMPLE AND RECONNECTED PLUMBING						
21				AND LEFT SYSTEM IN SERVICE. WELL						
22				PUMP WAS REFILLING TANK WHEN						
23				TECH DEPARTED.						
24										
25	1	EA	330000	BACTI SAMPLE	1		93.35	/EA	93.35	N
26	6.25	HR	4550	WELL TESTING	6.25		150.00	/HR	937.50	N
27										
28				RESULTS TO FOLLOW						

TAXABLE 0.00
NON-TAXABLE 1030.85
** PAID IN FULL **

1030.85

SUBTOTAL 1030.85

SUBTOTAL 1030.85

TAX AMOUNT 0.00

TOTAL 1030.85

1030.85

BANKCARD PAYMENT
BKCARD#XXXXXXXXXXXX1100

TOT WT: 0.00

APP: 098171

XR: 335390

Received By

THIS SALE IS SUBJECT TO OUR TERMS & CONDITIONS POSTED IN STORE AND ONLINE AT WWW.FARMSUPPLYCOMPANY.COM.
TERMS & CONDITIONS ARE SUBJECT TO CHANGE WITHOUT PRIOR NOTIFICATION.

82123000D353901310018

MID: ***7935

Abalone Coast Analytical, Inc.

141 Suburban Rd, Ste C-1 San Luis Obispo CA, 93401
Phone: 595-1080 Fax: 595-1075

Order #: 26-3114
Date/Time Rec'd: 7/21/26 1543

Farm Supply Company
224 Tank Farm Road
San Luis Obispo, CA 93401

Contact: Brent Cabral
Phone: 805-540-6192
Sampler: Brent Cabral

P.O. 54855001

Project: RICHARD BURKETT

Sample #	Sample Description	Date / Time	Analysis	Method	Result	Units	RL	Completed
-1	1415 San Marco Rd	7/21/26 1400	Total Coliform	SM 9223 B.	Present	/100ml	1	07/22/26
			E-coli	IDEXX	Absent	/100ml	1	07/22/26

Report Completion Date:

7/22/26

Reviewed By:



Priyanka Singh, Technical Director

Definitions:

Absent = Less than 1 CFU/100mLs

Present = 1 or more CFU/100mLs

CFU = Colony Forming Unit

RL = Reporting Limit

State of California CDPH ELAP 2661

Coliform are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of Fecal coliforms and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.



San Luis Obispo County

FARM SUPPLY COMPANY

P.O. Box 111 • San Luis Obispo, California 93406 • 805.543.3571
2450 Ramada Drive • Paso Robles, California 93446 • 805.238.1177

☐ Record Only Acct

☐ Farm Supply Charge

☐ Contract

☐ Credit Card Authorization Form

Owner RICHARD BURKETT Acct No. 82123 Date 7/21/2026

Address 1415 SAN MARCOS RD Phone 213.810.3907

Email MRBARBBURKETT@GMAIL.COM

Called By BILLIE JO RALLS Phone 805.878.5582

SWL 84 Casing Size 8 Discharge Size 3 + 2
Well Depth Pump Depth Test Pump Size
HP Volts 230 Phase 3 PHASE
Start Time 10:00 Time of Shut Down 2:00 Hours of Running 4

Flowmeter Size 2

Flowmeter Totalizer Beginning 463837

Flowmeter Totalizer Ending

TECHNICIAN: TRAVIS

TEST PUMP DATA

DATE	TIME	PWL	G.P.M	Draw Down (FT)	PSI		Recovery Time	Feet	
7/21/26	10:00 AM	84	56				5 MIN	39	
	10:15 AM	184	50	100			10 MIN	59	
	10:30 AM	192	45	108	33		15 MIN	70	
	10:45 AM	191	40	107	55		20 MIN	79	
	11:00 AM	191	37	107	60				
	11:15 AM	191	37	107	60				
	11:30 AM	191	36	107	61				
	11:45 AM	191	36	107	61				
	12:00 PM	191	36	107	61				
	12:15 PM	191	36	107	61				
	12:30 PM	191	35	107	61				
	12:45 PM	191	35	107	61				
	1:00 PM	191	35	107	61				
	1:15 PM	191	35	107	61				
	1:30 PM	191	35	107	61				
	1:45 PM	191	35	107	61				
	2:00 PM	191	35	107	61				

Well Test Notes

Observe, note and document any abnormalities

SAND TESTING

mL
Time

PPM Sand #DIV/0!

Signed: Josh Tannea

Date: 6/12/2026