



PO Box 391578 • Anza, CA 92539 • Lic. 813456 C-55, C-57
(951) 763-2210 Office • (951) 602-6320 Fax
heritagewellservice@yahoo.com • www.heritagewellservice.com

April 10, 2024

Chris Kostecka
863 Greystone Place
San Luis Obispo, CA 93401

RE: 48910 Forest Springs Rd. Aguanga, CA
APN 584-310-006

Mr. Kostecka,


Below is a summary of our findings completed to investigate the well on the aforementioned property:

- 6/25/23 Initial visit to property, collected well GPS coordinates: 33.527352, -116.807020, well meets setbacks from property lines of required 50', old equipment in hole, needs to be removed for further investigation.
- 7/25/23 Removed pump from well, took measurements. Well Depth = 318' Static = 121' Casing = 6"
- 9/5/23 Completed Well Evaluation Application through Riverside County DEH, no well completion report on file, evidence and letter attached

Regards,

Megan Haley
Managing Member

Enclosures





County of Riverside
DEPARTMENT OF ENVIRONMENTAL HEALTH

P.O. BOX 7909 • RIVERSIDE, CA 92513-7909
JEFF JOHNSON, DIRECTOR

APPLICATION STATUS - CORRECTION REQUIRED

**APPLICATIONS FOR WATER WELL EVALUATION PERMIT
WP31248**

DATE: 08/24/2023

LEGAL DESCRIPTION: APN 584-310-006

APPLICANT: Heritage Well Service

OWNER: Chris Kostecka

Applications for the above referenced water well permits at the above parcel has been denied and requires the following items to be addressed:

- Observed incorrect well completion report for an adjacent parcel. Provide a correct well completion report for lot 885.
- Observed missing flow test. Provide a current 4 four flow test.
- **Please note additional information may be required upon review of new information.**

IMPORTANT NOTE: No inspection of your site will be conducted, or approval granted to operate, until all proper information requested has been received and your approved plans have been returned to you. Plans must be reviewed, approved, stamped, and returned to you by this Department prior to any construction work beginning. Upon completion of plan review a set of stamped, approved plans will be returned to the applicant for further review of any other applicable agency.

Sincerely,

Brittany Porto

Environmental Health Specialist III
Department of Environmental Health
Land Use and Water Division
(951) 955-8980

WELL DATA RECORD

TECH: David T DATE: 06/27/23

Customer Information:

Name:

Chris Kostecky

Property Address:

Apn 584310006

GPS Coordinates to Well:

33.527352 116.807020

Well Depth:

unknown

Static:

unknown

Inner Casing Size:

unknown

Outer Casing Size:

6"Material: ☐ PVC ☐ SteelMaterial: ☐ PVC ☒ SteelEvidence of Sanitary Seal?: ☒ Yes ☐ NoConcrete Slab installed?: ☐ Yes ☒ Noconcrete

Size:

Configuration on Property (Draw map with distance to property line if known)

well

Brush

Hill

Forest Springs

Notes:

Brush needs to be cleared
around well and road cut in
pump still in hole.

Wire none sub cable #12 going Down

This system has been professional designed and installed by Heritage Well Service LLC

PO Box 391578 Anza, CA 92539 • Lic 813456 C-55, C-57

(951) 763-2210 Office • (951) 602-6320 Fax

heritagewellservice@yahoo.com • www.heritagewellservice.com