



Paradise Sanitation Company, Inc.
PO Box 3815
Paradise, CA 95967
530-877-3207
paradis sanitation@gmail.com

Address: 5985 McClain Name: Larry Poe Date: 09/24/26

Evaluator License Number

S-501

Access Risers in Place

No

Sanitary Tee-Inlet

Yes

Scum Depth, Inlet Compartment (inches)

13

Sludge Depth, Inlet Compartment (inches)

10

Structural Tank Condition

Good

Liquid Operating Level

Normal

Liquid from Operating Level Distance (inches)

0

Baffle Condition

Good

Septic Tank Volume (gallons)

1500

Riser Condition

-

Sanitary Tee-Outlet

Yes

Scum Depth, Outlet Compartment (inches)

0

Sludge Depth, Outlet Compartment (inches)

7

Tank Material

Concrete

Tank Material Description if Other

-

Was Septic Tank Pumped

Yes

Volume of Waste Pumped (gallons)

1500

Waste Deposited at Landfill Station

Yes

Depth to Septic Tank Access Lid-Inlet (inches)

16

Depth to Septic Tank Access Lid-Outlet (inches)

12

Effluent Pump

No

Effluent Line Diverter Valve

No

Well on Property

No

Common Area/Community Absorption Field

No

Absorption Field Type

Standard

Surfacing Effluent

No

Hydraulic Load Test

Yes

Hydraulic Load Test Results

Good

Down Slope Seepage

No

Saturated Absorption Field

No

Multiple Systems

No

Graywater Discharge

No

Occupancy Type

Single Family

Space(s)/Unit Number(s)

-

Evaluation Date Performed

September 24, 2026


Pumping Date Performed

-

Evaluator Comments

Tank inspected on standing home, in good condition and operating at normal liquid level. Absorption field tested Good.

This Onsite Wastewater Treatment and Disposal System Evaluation Report is a true and complete record of the septic system on the date of evaluation. No warranty is given or implied regarding the remaining life of the system. I certify that this Onsite Wastewater Treatment and Disposal System Evaluation Report reflects conditions on the parcel(s) during the routine maintenance of the Onsite Wastewater Treatment and Disposal System.



Map is not to scale and is for reference
only