

State of California
Well Completion Report
Form DWR 188 Submitted 7/6/2021
WCR2021-008229

Owner's Well Number _____ Date Work Began 06/25/2021 Date Work Ended 06/29/2021
Local Permit Agency County of Riverside Department of Environmental Health
Secondary Permit Agency _____ Permit Number WP0029880 Permit Date _____

Well Owner (must remain confidential pursuant to Water Code 13752)		Planned Use and Activity	
Name <u>[REDACTED]</u>	Activity <u>New Well</u>	Mailing Address <u>[REDACTED]</u>	Planned Use <u>Water Supply Domestic</u>
City <u>[REDACTED]</u> State <u>[REDACTED]</u>			

Well Location			
Address <u>0 Sweetbush Lane</u>		APN <u>577-420-034</u>	
City <u>Anza</u>	Zip <u>92539</u>	County <u>Riverside</u>	
Latitude <u>33</u> <u>30</u> <u>28.692</u> <u>N</u>	Longitude <u>-116</u> <u>35</u> <u>27.1751</u> <u>W</u>	Township <u>08 S</u>	
Deg. Min. Sec.	Deg. Min. Sec.	Range <u>04 E</u>	
Dec. Lat. <u>33.50797</u>		Section <u>05</u>	
Dec. Long. <u>-116.590882</u>		Baseline Meridian <u>San Bernardino</u>	
Vertical Datum _____		Ground Surface Elevation _____	
Horizontal Datum <u>WGS84</u>		Elevation Accuracy _____	
Location Accuracy _____		Elevation Determination Method _____	
Location Determination Method _____			

Borehole Information	Water Level and Yield of Completed Well
Orientation <u>Vertical</u> Specify _____	Depth to first water _____ (Feet below surface)
Drilling Method <u>Downhole Hammer</u> Drilling Fluid <u>Foam</u>	Depth to Static _____
Total Depth of Boring <u>600</u> Feet	Water Level _____ (Feet) Date Measured <u>06/29/2021</u>
Total Depth of Completed Well <u>600</u> Feet	Estimated Yield* <u>6</u> (GPM) Test Type _____
	Test Length <u>2</u> (Hours) Total Drawdown _____ (feet)
	*May not be representative of a well's long term yield.

Geologic Log - Lite					
Depth from Surface Feet to Feet		Material Type	Material Color	Material Texture	Material Description
0	20	Soil or Organic			
20	40	Granite		Clayey	
40	80	Granite			
80	100	Granite		Clayey	
100	140	Granite			
140	180	Granite		Clayey	
180	240	Granite			
240	260	Granite		Clayey	
260	280	Granite		Fractured	
280	300	Granite			
300	320	Granite		Fractured	
320	340	Granite		Clayey	
340	360	Granite			
360	380	Granite		Fractured	
380	440	Granite			

440	460	Granite		Clayey	
460	520	Granite			
520	540	Granite		Clayey	
540	600	Granite			

Casings										
Casing #	Depth from Surface Feet to Feet		Casing Type	Material	Casings Specifications	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0	20	Conductor or Fill Pipe	Low Carbon Steel	Grade: ASTM A36	0.188	8.625			
2	0	400	Blank	PVC	OD: 4.950 in. SDR: 17 Thickness: 0.291 in.	0.291	4.95			
2	400	420	Screen	PVC	OD: 4.950 in. SDR: 17 Thickness: 0.291 in.	0.291	4.95	Milled Slots	0.32	
2	420	440	Blank	PVC	OD: 4.950 in. SDR: 17 Thickness: 0.291 in.	0.291	4.95			
2	440	460	Blank	PVC	OD: 4.950 in. SDR: 17 Thickness: 0.291 in.	0.291	4.95			
2	460	480	Screen	PVC	OD: 4.950 in. SDR: 17 Thickness: 0.291 in.	0.291	4.95	Milled Slots	0.32	
2	480	500	Blank	PVC	OD: 4.950 in. SDR: 17 Thickness: 0.291 in.	0.291	4.95			
2	500	520	Screen	PVC	OD: 4.950 in. SDR: 17 Thickness: 0.291 in.	0.291	4.95	Milled Slots	0.32	
2	520	540	Blank	PVC	OD: 4.950 in. SDR: 17 Thickness: 0.291 in.	0.291	4.95			
2	540	560	Screen	PVC	OD: 4.950 in. SDR: 17 Thickness: 0.291 in.	0.291	4.95	Milled Slots	0.32	
2	560	580	Blank	PVC	OD: 4.950 in. SDR: 17 Thickness: 0.291 in.	0.291	4.95			
2	580	600	Screen	PVC	OD: 4.950 in. SDR: 17 Thickness: 0.291 in.	0.291	4.95	Milled Slots	0.32	

Annular Material				
Depth from Surface Feet to Feet		Fill	Fill Type Details	Filter Pack Size
0	20	Bentonite	Low Solids	
0	600	Other Fill	See description.	Chipped rock

Other Observations:
