DocuSign Envelope ID: 0ED8DA2E-F183-4BA4-9FC1-1110A513FB36

Abalone Coast Analytical, Inc.
141 Suburban Rd, Ste C-1 San Luis Obispo CA, 93401
Phone: 595-1080 Fax: 595-1075
ELAP #2661

Order #: 24-2007
Date/Time Rec'd: 5/8/24 1319

Miller Drilling Company
301 North Main Street
Templeton, CA 93465

Contact: Eric Thomas
Phone: 434-1888
Sampler: Casey

Project:

Sample #	Sample Description	Date / Time	Analysis	Method	Result	Units	RL	Completed
-1	**#28708 -- Kohn**	5/8/24 0916	Total Coliform	SM 9223 B.	**Absent**	/100ml	1	**05/09/24**
	1630 Cumbre Rd		*E-coli*	IDEXX	**Absent**	/100ml	1	**05/09/24**

This sample passes water quality standards for Total Coliform and E. Coli Bacteria.

Report Completion Date: **5/9/24**

Reviewed By: _____
Priyanka Singh, Technical Director

Definitions:
Absent = Less than 1 CFU/100mLs
Present = 1 or more CFU/100mLs
CFU = Colony Forming Unit
RL = Reporting Limit

State of California CDPH ELAP 2661

Coliform are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of Fecal coliforms and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

DocuSign Envelope ID: 0ED8DA2E-F183-4BA4-9FC1-1110A513FB36

DS
PT

Miller Drilling Co.
329 N. Main St.
Templeton, CA 93465
(805) 434-1888

Miller Drilling Co.

Contractors License No. 324634

PUMP TEST REPORT

Job#: 28708

WELL OWNER: Randy Kohn
BILLING ADDRESS: 1630 Cumbre Rd
Paso Robles, CA 93446
randocomando@sbcglobal.net

Pump Set:
Well #: 5 IN
Pump Size: 2 HP
Well Depth:
Testing Method: Exisiting Submersible
Perf Rec: N/A
APN: 020-461-009
LOCATION: 1630 Cumbre Rd

Standing Level Before Test: 312 FT

TESTING

TIME	PUMPING LEVEL	WATER CONDITION	WATER/BOWLS	GPM
8:45 AM		CLEAR ODOR		
8:58 AM	318 FT	CLEAR ODOR		14
9:08 AM	318 FT	CLEAR ODOR		14
10:15 AM	320 FT	CLEAR		14
10:28 AM	320 FT	CLEAR		14
10:58 AM	320 FT	CLEAR		14
11:09 AM	320 FT	CLEAR		14
11:39 AM	320 FT	CLEAR		14
12:39 PM	320 FT	CLEAR		14
12:45 PM	320 FT	CLEAR		14

Notes:

STANDING LEVEL AFTER TEST: 314 FT AFTER 10 MIN RECOVERY
FINAL TEST RESULTS: Produced: 14 GPM for 4 hours on: 5/8/2024
Test Run By: CASEY