

Porter Special Utility District - Customer Service Inspection

Porter Special Utility District
22162 Water Well Road
Porter, Texas 77365

PWS ID: 1700068
Phone Number:
Email Address:

Inspector Information

Company Name: Upcity Inspections
Title of Inspector:
Inspector Name: Moises Licona
Address: 18844 Forest Ln
Porter, Texas 77365

Phone Number: 3466973797
Email Address: emirlic@hotmail.com
License Number: CI0012090
License Type: TCEQ - CSI License

Location Information

Property Type: Residential
Business Name:
Property Address: 21563 Lexor Ct
Porter, TX 77365

Contact Information

Company Name:
Contact Name:
Mailing Address: 21563 Lexor Ct
Porter, TX 77365
Phone Number:
Email Address:

Inspection Results

Reason for Inspection: Existing service where contaminant hazards are suspected

Inspection Date: 7/6/2026 3:50 PM

I, Moises Licona, upon inspection of the private water distribution facilities connected to the aforementioned public water supply do hereby certify that, to the best of my knowledge:

1. No direct or indirect connection between the public drinking water supply and a potential source of contamination exists. Potential sources of contamination are isolated from the public water system by an air gap or an appropriate backflow prevention assembly in accordance with Commission regulations.
2. No cross-connection between the public drinking water supply and a private water system exists. Where an actual air gap is not maintained between the public water supply and a private water supply, an approved reduced pressure principle backflow prevention assembly is properly installed.
3. No connection exists which would allow the return of water used for condensing, cooling or industrial processes back to the public water supply.
4. No pipe or pipe fitting which contains more than 8.0% lead exists in private water distribution facilities installed on or after July 1, 1988 and prior to January 4, 2014.
5. Plumbing installed on or after January 4, 2014 bears the expected labeling indicating =0.25% lead content. If not properly labeled, please provide written comment.
6. No solder or flux which contains more than 0.2% lead exists in private water distribution facilities installed on or after July 1, 1988.

Compliance Non-compliance

●	○
●	○
●	○
●	○
●	○
●	○

I further certify that the following materials were used in the installation of the private water distribution facilities:

Service Lines: ☐ Lead ☐ Copper ☒ PVC ☒ Pex
Solder: ☐ Lead ☐ Lead Free ☒ Solvent Weld ☒ Compression

☒ I recognize that this document shall be retained by the aforementioned Public Water System for a minimum of ten years and that I am legally responsible for the validity of the information I have provided.

Remarks

Public sewer
Vacuum breakers
No filters
No water fixtures