



www.MyAccurateHomeServices.com

AccurateInspect

www.accurateinspect.com

PO Box 14423

Humble, Texas 77347

281-745-0234 - office

2015 IECC Energy Testing

For more information, refer to the following sections in the 2021 IECC: *R402.4 Air leakage (Mandatory)*, *R402.4.1.2 Testing*, *R403.3.3 Duct testing (Mandatory)*, *R403.3.4 Duct leakage (Prescriptive)*

PROJECT INFORMATION	
Project Address: <u>703 Short Mill Run, Montgomery, TX 77316</u>	Project #: _____
Test Date: <u>08-10-2026</u>	
Type of Energy Compliance: ☐ (R-8) Prescriptive ☐ (R-6) Performance	
BUILDING ENVELOPE AIR LEAKAGE TEST RESULTS (SEC. 402.4.1.1)	
Test in accordance with ASTM E 779 or ASTM E 1827 and reported at a pressure of 0.2 in. w.g. (50 Pascals)	☐ Pass
Target CFM at ACH/50: _____ Actual CFM at ACH/50: _____	☐ Fail
Whole-house Ventilation Required: ☐ YES ☐ NO	
DUCT LEAKAGE TEST RESULTS (SEC. 403.3.3 & 403.3.4) Target : 4 CFM per 100 sq. ft. conditioned space <i>Depressurization of duct system</i>	
SYSTEM #1	
Target Duct Leakage CFM: _____ Actual Duct Leakage CFM: _____	☐ Pass
<i>Exception: Duct Leakage Test is not required where ducts & air handlers are located entirely within the building thermal envelope.</i>	☐ Fail
	☐ Exempt
SYSTEM #2	
Target Duct Leakage CFM: _____ Actual Duct Leakage CFM: _____	☐ Pass
<i>Exception: Duct Leakage Test is not required where ducts & air handlers are located entirely within the building thermal envelope.</i>	☐ Fail
	☐ Exempt
SYSTEM #3	
Target Duct Leakage CFM: _____ Actual Duct Leakage CFM: _____	☐ Pass
<i>Exception: Duct Leakage Test is not required where ducts & air handlers are located entirely within the building thermal envelope.</i>	☐ Fail
	☐ Exempt

Name of Technician Larry Ty Fleming

Signature [Signature] 08-10-2026

IECC #5188493