



Your Radon Test Information

August 9, 2026

Dates of Test: 2026-02-23 @ 2:00 pm to 2026-03-02 @ 2:00 pm				
Property Address	Test Number	Location	Analysis Date	Result
3515 BROKEN BOW TRL DELAFIELD, WI 53018	21043580	Basement Basement	2026-03-06	23.6 ± 1.9 pCi/L
Interpreting Your Test Result				
Your test result is above the US EPA action levels of 4.0 pCi/L. The EPA recommends that houses with more than 4.0 pCi/L be mitigated to lower the radon concentrations. If you would like a mitigation consultation with your AprilAire Dealer, we have included their contact information below for your convenience.				
Closed house conditions maintained during test.				

Certified Dealer

Find a certified Radon Professional near you:
<https://www.aprilaire.com/find-a-pro>

Device Information

Air Chek Activated Charcoal
Serial #: 21043580
Analyzed by: Air Chek, NC
NRPP Lab ID: 101138 AL

For questions, contact:
support@aprilaire.com

The laboratory analysis has been performed to comply with National, State, and Local guidelines for radon testing. This report represents the average radon concentration at the time of sampling and at the specific location in the building. However, it must be noted that radon concentrations will vary from day to day and from season to season.

Limitation of liability: While we at Air Chek make every effort to maintain the highest possible quality control and include several checks and verification steps in our procedures, we make no warranty of any kind, expressed or implied, including without limitation any implied warranty of merchantability or fitness with respect to any item furnished, information supplies or services rendered you by Air Chek. Neither Air Chek nor any of our employees or agents, shall be liable under any claim, charge, or demand, whether in contract, tort or otherwise, for any and all losses, costs, charges, claims, demands, fees, expenses, injuries, or damages (including without limitation incidental or consequential damages which are excluded) of any nature or kind arising out of, connected with, resulted from, or sustained as a result of any item furnished, information supplied, or service rendered to you by Air Chek.



Your Radon Test Information

Retesting

It is important to understand that radon levels can change at some point in the future. Therefore, it is important to retest when there is occupancy by a new owner, before and after a new addition to the house, alterations that could alter ventilation patterns, if major cracks are noticed in foundation walls or the slab, you begin using a ground contact area of the home not previously tested, or even recent nearby construction blasting or earthquakes. EPA recommends that homes be retested every 2-3 years. If the home has been previously mitigated or alterations are made to the mitigation system, retesting should be done.

Mitigation

When radon mitigation is necessary, it is advisable that a state-licensed or nationally-certified contractor be used to design and install the mitigation system. For easy to read mitigation information, go to the US EPA website and download a copy of the Consumer's Guide to Radon Reduction.

For technical information, call (800) 334-6011. Office hours are Mon-Fri 7:30am to 5:00pm Central Standard Time.