



This map is intended for advisory purposes only. This information has been obtained from sources believed to be reliable based on plats, survey, and other records. In areas where discrepancies occur between equivalent legal records, the discrepancy is allowed to remain until such time as it is addressed. Sheboygan County distributes this data on an "as is" basis and warranties are implied.



Date Printed: 9/23/2026

ArcGIS Web Map

0 0.01 0.02 mi
+ + + + +



Permit

Permit Type	Sanitary	Permit No.	8626	Application No.	
State Transaction		County No.			
Permit Subtype	Replacement System	Additional Types			
Building Type	<None>	Addl. Explanation	1F-3		
Original Applicant	ARPKE, RODNEY F. &				
Additional Info					
WI Fund Date		WI Fund Amount	0	☐ ISD	
Application Date		Issued On	12/18/2007	Expires On	12/17/2009
Permit Status	Approved	Permit Issuer	None		
Contact Phone		Contact Email			

Document

Properties

Parcel Number	District Name	Alt. Parcel #	Site Address	Receives Mail	Percent Ownership	Action
59004032050	Town of Herman		N9263 WILLOW RD	☒	100%	View

Powts System

System Type	At-Grade	Installer	
Design Flow(gpd)	450	Soil Application Rate(gpdsf)	0.4
Soil Horizon ^d	None	System Elevation	103.25
		Final Inspection	6/26/2008
		Status	Active

	Capacity New	Capacity Existing	Total	Compartments	Tanks	Manufacturer	Type
Tank	1000		1000	1	1	Ledgeview	Prefab Concrete
Chamber	500		500	1			
Pretreatment			0				

▼ Components

Components

Type	Manufacturer	Interval	Last Service	Next Service	Status	Description	Restricted Service
At-Grade	Stone	36	10/10/2025	10/10/2028	Current		
Effluent Filter	Orenco Systems	36	10/10/2025	10/10/2028	Current	ES 1548	
Pump Chamber	Ledgeview Precast Concrete Inc.	36	10/10/2025	10/10/2028	Current	500	
Pump	Zoeller	36	10/10/2025	10/10/2028	Current	140	
Septic Tank(s)	Ledgeview Precast Concrete Inc.	36	10/10/2025	10/10/2028	Current	1000	

▼ Maintenance

Maintenance Reports

Service Date	Filed Date	Gallons	Maintenance Company	Filed By	Action
10/10/2025	11/5/2025	1200	Harper Pumping, LLC	Andrew Harper	View
7/8/2022	8/22/2022	1200	Cascade Septic Tank Cleaning	Steve McCarty	View
7/8/2022	7/11/2023	0	Dirkse and Huibregtse LLC	Damon Huibregtse	View
4/1/2020	4/6/2020	0	Ziegelbauer Septic Service	Jenny Ziegelbauer	View
4/4/2017	4/4/2017	1200	Ziegelbauer Septic Service	Jenny Ziegelbauer	View
2/15/2014	2/18/2014	1200	Ziegelbauer Septic Service	Jenny Ziegelbauer	View

▼ Fees

Fees

There are no fees associated with this permit

▼ Notices

Notices

Type of Notice	End Date of Batch	Batch Creation Date
First Notice	7/10/2020	4/2/2020
First Notice	7/8/2023	4/7/2023
First Notice	9/26/2025	6/27/2025
Violation	10/6/2025	10/6/2025