

PRIVATE Water Sample Collection Information Form

Collection Date (MM/DD/YY) 4/14/26 Time: 11:00 ☒ AM ☐ PM		Owners Email Address topchoice4663@gmail.com	
Owners Name GARRICK OLERUD		Owners Telephone Number ()	
Owners Street Address		Well Address (Street or Legal Description) E6993 Cty. Rd. Y	
City, State, Zip Code		Town or City VIROQUA	County VERNON
Pricing effective 01/01/2024 Pricing subject to change Call for current pricing if this is an old form Mail Results to		Name	
		Address	
		City	State Zip Code
Sampling information and Test Requests		LABORATORY RESULTS - Laboratory use only	
☒ Bacteriological/E.Coli \$30 ☐ Colony Count + \$10 ☒ Nitrate \$30 ☐ Arsenic \$30 ☐ Lead \$30 ☐ Iron \$20 ☐ Other:		Bacteriological Approved Method ☒ MMO-MUG (Colisure) ☐ Membrane Filter ☐ Presence/Absence	
Mailed Kit \$8.00		Bacteriological Interpretation: ☒ SAFE (Coliform Absent) Colony Count Bacteria: _____ Colony Count Fecal/E.Coli: _____ ☐ UNSAFE (Coliform Present) and: ☐ Fecal/E.Coli Present ☐ Fecal/E.Coli Absent	
*Payment and Paperwork must be included with sample for analysis. <i>If you are interested in other testing, please call.</i>		☐ Invalid (over 48 hours) ☐ Invalid Chlorine Present	
Private Sample Information Only		Arsenic: _____ ug/L DNR recommends that you stop using your water for drinking or food prep if Arsenic level is greater than 10 ug/L (ppb)	
Reason for Test: ☐ Annual Test ☒ Real Estate ☐ Taste/Odor ☐ Previous Unsafe		Nitrate: 11.468 mg/L as N DNR state that water is considered unsafe for infants under 1 year of age and pregnant women when nitrate level is greater than 10 mg/L (ppm)	
Sample Location: ☐ Bath Tap ☒ Pressure Tnk. Tap ☐ Kitchen Tap ☐ Milk house Other _____		Other: _____ : _____ mg/L or ug/L Other: _____ : _____ mg/L or ug/L	
Total Paid _____ Staff Initials _____		Date/Time Received 4.15.26	
Payment method _____		Lab Sample Number A936	
LV Labs WW, LLC 1015 S Madison St, PO Box 384 Lancaster, WI 53813 (608) 723-4096 Lvlabs.DW@gmail.com		Date Reported 4.16.26 Date Received by DNR	

Sampling Disclaimer

LV Labs WW, LLC reserves the right to reject any sample that is received non-compliant. All sample(s) must be received within 48 hours from the time the sample is collected. Sampler will be notified of sample rejection. If sampler requests testing to be done upon notification of sample rejection, LV Labs WW, LLC. LV Labs will keep copies for five years before disposal.