

Clean Water Testing
1990 Prospect Ct
Appleton, WI 54914 US

Invoice
9005384269

SHIP TO: TUCKER SCHUETT /1701605 N7097 Nielson Ln Johnson Creek, WI, 53038-9776 US PH: 920-650-3153 FAX:	INFORMATION: Invoice Date: 11/10/2021 Order No: 1002703586 Order Date: 11/10/2021 PO Number: 579561 PO Date: 11/10/2021 Delivery No: BOL No: Carrier: Tracking Info: Ship Date:
PAYER: TUCKER SCHUETT /1701605 N7097 Nielson Ln Johnson Creek, WI 53038-9776 US PH: 920-650-3153 FAX:	
TERMS: Terms: Paid with Check Inco Terms: EXW/PLANT Inv Due Date: 11/10/2021 Currency: USD	REMIT TO: CLEAN WATER TESTING 1990 PROSPECT CT. APPLETON, WI 54914

ADDITIONAL HEADER INFORMATION:

PAID

ITEM#	MATERIAL # / DESCRIPTION	QTY	UOM	UNIT PRICE	TOTAL VALUE
10	100250070 WELL WATER QUALITY PACKAGE	1	EA	199.00	199.00
	Delivering Plant - Clean Water Testing				
				SUBTOTAL	199.00
				FREIGHT	0.00
				TOTAL TAXES	0.00
				TOTAL AMOUNT DUE	199.00

Buyer shall pay Seller the full purchase price as set forth in Seller's Documentation. Unless Seller's Documentation provides otherwise, freight, storage, insurance and all taxes, duties or other governmental charges relating to the Goods shall be paid by the Buyer. If Seller is required to pay any such charges, Buyer shall immediately reimburse Seller. All payments are due within 30 days after receipt of invoice. Buyer shall be charged the lower of 1 1/2 % interest per month or the maximum legal rate on all amounts not received by the due date and shall pay all of Seller's reasonable costs (including attorneys' fees) of collecting amounts due but unpaid. All orders are subject to credit approval.

ANY WARRANTIES PROVIDED WILL BE AS ATTACHED TO THE PARTICULAR GOODS OR PRODUCT

Tel. 800-801-7590

<http://www.cleanwatertesting.com>

Page 1 of 1

Fax.



1990 Prospect Ct., Appleton, WI 54914 * 800-801-7590

TUCKER SCHUETT
N7097 Nielson Ln
JOHNSON CREEK, WI 53038

Home Owner TUCKER SCHUETT
Well ID/Address N7097 NIELSON LN
Well City JOHNSON CREEK, WI 53038
Sample Location OUTSIDE FAUCET
Lab # 579561
Collected By/Date TUCKER SC 11/9/2021

Report Date 01-Dec-21

Analyte	Result	Units	LOD	LOQ	Dil	Dig	Date	Run Date	Mthd	Analyst	QC Code
---------	--------	-------	-----	-----	-----	-----	------	----------	------	---------	---------

General

Wet Chemistry

Chlorides	18.9	mg/l	2.19	7.3	1		11/10/2021	300.0		1
------------------	------	------	------	-----	---	--	------------	-------	--	---

(as Cl) Small amounts of chloride are natural; the chloride ion is one of the major inorganic anions in water. However, levels above 200 mg/L are undesirable and often unnatural. They can indicate road salt, septic waste or fertilizer contamination.

Sulfate	66.0	mg/l	2.77	9.23	1		11/10/2021	300.0		1
----------------	------	------	------	------	---	--	------------	-------	--	---

(SO₄)...There is currently no primary standard for sulfate. A secondary standard of 250 mg/l has been established. Small amounts of sulfates are natural. Levels above 250 mg/l are undesirable; they can cause odors, leave spots, taste bitter and may have a temporary laxative effect.

Inorganic

General

Fluoride	None Detected	mg/l	0.23	0.77	1		11/10/2021	300.0		1
-----------------	---------------	------	------	------	---	--	------------	-------	--	---

(F)...Fluoride is natural in water. Levels around 1.0 mg/L are desirable; levels above 4.0 mg/l may stain teeth. Supplements may or may not be necessary for infants depending on the level contained in your water supply.

Nitrate Nitrogen	4.44	mg/l	0.08	0.27	1		11/10/2021	4500F		1
-------------------------	------	------	------	------	---	--	------------	-------	--	---

NITRATE (as NO₃+NO₂)...A small amount of nitrate may be natural; however, elevated levels are an indication of nutrients entering the groundwater due to human activity. The maximum contaminant level set by the EPA is 10 mg/L (part per million).

Metals

Aluminum	None Detected	ug/l	8.4	28	1		12/1/2021	200.7	NMP	1
-----------------	---------------	------	-----	----	---	--	-----------	-------	-----	---

(as total Al)...Aluminum is the third most common element in the earth's crust and is present in soil, water and air. Intake of large amounts of aluminum can cause anaemia, osteomalacia (brittle or soft bones), glucose intolerance, and cardiac arrest in humans. We do not know the effects in humans exposed to low levels of aluminum over a long period, but earlier onset or progression of a wide range of diseases of the nervous system is a possibility. For these reasons, aluminum is listed as a secondary contaminant and has a maximum contaminant limit of 200 ug/L (ppb).

Arsenic, Total	5.6	ug/l	0.8	2.7	1		11/11/2021	3113B	AS	1
-----------------------	-----	------	-----	-----	---	--	------------	-------	----	---

(as total As) Elevated arsenic levels are believed to cause skin cancer, and blood and nervous system disorders. The EPA and the WI DNR consider levels above 10 ug/L (parts per billion) in drinking water harmful.

Please visit our website at www.cleanwatertesting.com

WI DNR Lab Certification # 445126660

EPA ID# WI00063

WI Dept of Ag Lab ID # 152673-D3

Page 1 of 5



1990 Prospect Ct., Appleton, WI 54914 * 800-801-7590

TUCKER SCHUETT
N7097 Nielson Ln
JOHNSON CREEK, WI 53038

Home Owner TUCKER SCHUETT
Well ID/Address N7097 NIELSON LN
Well City JOHNSON CREEK, WI 53038
Sample Location OUTSIDE FAUCET
Lab # 579561
Collected By/Date TUCKER SC 11/9/2021

Report Date 01-Dec-21

Analyte	Result	Units	LOD	LOQ	Dil	Dig	Date	Run Date	Mthd	Analyst	QC Code
Barium	71.5	ug/l	1.7	5.5	1		12/1/2021	200.7	NMP		1

(as total Ba) Barium is naturally occurring in groundwater and appears in pockets of elevated levels. High levels of barium have severe toxic effects on the heart, blood vessels and nerves. The EPA has set the maximum contaminant level for barium at 2000 ug/L (parts per billion). Barium is easily removed with a water softener, but will foul the media with time. Both the efficiency of your water softener and the barium levels in your water should be monitored.

Beryllium	None Detected	ug/l	0.2	0.8	1		12/1/2021	200.7	NMP		1
-----------	---------------	------	-----	-----	---	--	-----------	-------	-----	--	---

(as total Be) Beryllium occurs in nature as deposits of beryls in granitic rocks. Beryllium is used in metal alloys, x-ray machines, and nuclear reactors. The EPA has set a maximum contaminant limit of 4ug/L (parts per billion) in drinking water due to beryllium's toxicity to humans at low levels.

Cadmium	None Detected	ug/l	0.4	1.3	1		12/1/2021	200.7	NMP		1
---------	---------------	------	-----	-----	---	--	-----------	-------	-----	--	---

(as total Cd) The greatest use of cadmium is primarily for metal plating and coating operations; it is also used in nickel-cadmium and solar batteries and in pigments. Cadmium is extremely toxic and accumulates in the kidneys and liver with prolonged intake at low levels sometimes leading to dysfunction of the kidneys. The EPA primary drinking water standard maximum contaminant limit is 5 ug/L (parts per billion).

Calcium	82.0	mg/l	0.05	0.15	1		12/1/2021	200.7	NMP		1
---------	------	------	------	------	---	--	-----------	-------	-----	--	---

(as total Ca) Common constituent of water, derived from dissolved limestone and dolomite. Primary cause of hard water and scaling. The EPA does not regulate Calcium levels in drinking water.

Chromium	None Detected	ug/l	3.9	12.8	1		12/1/2021	200.7	NMP		1
----------	---------------	------	-----	------	---	--	-----------	-------	-----	--	---

(as total Cr) Chromium is used in metal alloys such as stainless steel, and its soluble forms are used in wood preservatives. Chromium is considered an essential trace nutrient for animals and humans; however the hexavalent form chromium has been shown to be carcinogenic. For these reasons, the EPA has set a maximum contaminant limit in drinking water at 100 ug/L (parts per billion) for total chromium.

Cobalt	None Detected	ug/l	2.3	7.5	1		12/1/2021	200.7	NMP		1
--------	---------------	------	-----	-----	---	--	-----------	-------	-----	--	---

(as total Co) Cobalt often occurs in nature with arsenic. It is used in the production of steels, fertilizers, and glass. Cobalt is an essential trace element for humans; however ingestion of high levels may cause nausea and vomiting. Inhalation of cobalt dust is toxic. The EPA does not regulate cobalt in drinking water.

Please visit our website at www.cleanwatertesting.com

WI DNR Lab Certification # 445126660

EPA ID# WI 00063

WI Dept of Ag Lab ID # 152673-D3

Page 2 of 5



1990 Prospect Ct., Appleton, WI 54914 * 800-801-7590

TUCKER SCHUETT
N7097 Nielson Ln
JOHNSON CREEK, WI 53038

Home Owner TUCKER SCHUETT
Well ID/Address N7097 NIELSON LN
Well City JOHNSON CREEK, WI 53038
Sample Location OUTSIDE FAUCET
Lab # 579561
Collected By/Date TUCKER SC 11/9/2021

Report Date 01-Dec-21

Analyte	Result	Units	LOD	LOQ	Dil	Dig Date	Run Date	Mthd	Analyst	QC Code
Copper - ICP	396	ug/l	3.1	10	1		12/1/2021	200.7	NMP	1
(as total Cu) Copper is toxic, especially to children, and is an irritant to the digestive tract. The presence of copper may tint blond hair greenish blue; and it may also cause staining of light-colored clothes. Water containing more the 1,300 ug/L (parts per billion) is likely to be providing amounts in excess of the normal human intake, but may not necessarily be toxic. The EPA's recommended Maximum Contaminant Level (1,300 ppb) is based on taste and total dietary intake, not toxicity.										
Iron	2.37	mg/l	0.03	0.1	1		12/1/2021	200.7	NMP	1
(as total Fe)...Iron is a naturally occurring metal that is present in most aquifers. Iron is a considered a Secondary Drinking Water Contaminant, meaning that there are no known health effects from the intake of iron. The current secondary standard is 0.3 mg/L (ppm). Iron levels above 0.3 mg/L in water may cause red to brown staining and may result in a metallic taste.										
Lead	3.0	ug/l	0.8	2.7	1		11/11/2021	3113B	AS	1
(as total Pb)...Excess levels of lead can cause damage to the brain, kidneys, nervous system, red blood cells and reproductive system. The EPA and DNR consider levels above 15 ug/L (parts per billion) harmful.										
Magnesium	47.9	mg/l	0.06	0.2	1		12/1/2021	200.7	NMP	1
(as total Mg)...Common constituent of water, derived from dissolved limestone and dolomite. Partner with calcium as the primary cause of hard water and scaling. The EPA does not regulate magnesium levels in drinking water.										
Manganese	18.3	ug/l	4.2	13.8	1		12/1/2021	200.7	NMP	1
(as total Mn)...Manganese tastes muddy, stains brown, and fouls water softeners, for these reasons, the EPA secondary drinking water maximum contaminate limit is 50 ug/L.										
Molybdenum	None Detected	ug/l	1.9	6.2	1		12/1/2021	200.7	NMP	1
(as total Mo)...Molybdenum is used in metal alloys and lubricants. It is considered an essential trace element for plants and animals. It is not known if intake of high levels of molybdenum causes adverse health affects. The EPA does not regulate molybdenum in drinking water.										

Please visit our website at www.cleanwatertesting.com

WI DNR Lab Certification # 445126660

EPA ID# WI 00063

WI Dept of Ag Lab ID # 152673-D3

Page 3 of 5



1990 Prospect Ct., Appleton, WI 54914 * 800-801-7590

TUCKER SCHUETT
N7097 Nielson Ln
JOHNSON CREEK, WI 53038

Home Owner TUCKER SCHUETT
Well ID/Address N7097 NIELSON LN
Well City JOHNSON CREEK, WI 53038
Sample Location OUTSIDE FAUCET
Lab # 579561
Collected By/Date TUCKER SC 11/9/2021

Report Date 01-Dec-21

Analyte	Result	Units	LOD	LOQ	Dil	Dig Date	Run Date	Mthd	Analyst	QC Code
Nickel	None Detected	ug/l	3.4	11.4	1	12/1/2021	200.7	NMP		1

(as total Ni)...Nickel is used in metal alloys, magnets, protective coatings, and batteries. Long-term exposure of high levels of nickel has the potential to cause decreased body weight, heart and liver damage, and skin irritation. The EPA had remanded the 100 ug/L MCL of nickel on February 9, 1995. This means that while many water suppliers continue to monitor nickel levels in their water, there is currently no EPA legal limit on the amount of nickel in allowed in drinking water.

Phosphate	None Detected	mg/l	0.57	1.9	1	11/10/2021	300.0			1
-----------	---------------	------	------	-----	---	------------	-------	--	--	---

(as Orthophosphate)...Phosphorus occurs in natural waters primarily as phosphates. They can enter surface water or well water from laundry and cleaning waste as surfactants (soaps) and farming operations (as fertilizers). Some phosphates are used in commercial water treatment and others are found in many foods. There is no maximum contaminant level for phosphate in drinking water.

Potassium	1.24	mg/l	0.09	0.29	1	12/1/2021	200.7	NMP		1
-----------	------	------	------	------	---	-----------	-------	-----	--	---

(as total K)...Potassium is a naturally occurring element and is an essential nutrient for both humans and plants. There are no known adverse health affects of high levels in drinking water and there is no EPA maximum contaminate limit for potassium. Elevated levels in well water can indicate agricultural runoff.

Silver	None Detected	ug/l	8.4	28	1	12/1/2021	200.7	NMP		1
--------	---------------	------	-----	----	---	-----------	-------	-----	--	---

(as total Ag)...Silver is a naturally occurring metal that is found in small amounts in the earths crust and ocean waters. Silver is widely used in photography, silverware, jewelry, mirrors, and batteries. It is not toxic to humans, but prolonged exposure can lead to grayish blue discoloration of skin, known as argria. For these reasons, silver is listed as a secondary contaminant and has a maximum contaminate limit of 100 ug/L (ppb) in drinking water.

Sodium	19.4	mg/l	0.19	0.62	1	12/1/2021	200.7	NMP		1
--------	------	------	------	------	---	-----------	-------	-----	--	---

(as total Na)...Sodium is a common element found in ground water and is an essential nutrient for humans. In large concentration it may affect persons with cardiac difficulties. The EPA has set a health advisory limit for sodium in drinking water for 200 mg/L (parts per million). Elevated levels in well water may indicate agricultural or road salt runoff.

Vanadium	None Detected	ug/l	5.6	18.8	1	12/1/2021	200.7	NMP		1
----------	---------------	------	-----	------	---	-----------	-------	-----	--	---

(as total V)...Vanadium is a rare element that is used in the production of steel and synthetic rubber. Studies suggest that vanadium may play a beneficial role in the prevention of heart disease. The EPA does not regulate vanadium in drinking water.

Please visit our website at www.cleanwatertesting.com

WI DNR Lab Certification # 445126660 EPA ID# WI00063 WI Dept of Ag Lab ID # 152673-D3

Page 4 of 5



1990 Prospect Ct., Appleton, WI 54914 * 800-801-7590

TUCKER SCHUETT
N7097 Nielson Ln
JOHNSON CREEK, WI 53038

Home Owner TUCKER SCHUETT
Well ID/Address N7097 NIELSON LN
Well City JOHNSON CREEK, WI 53038
Sample Location OUTSIDE FAUCET
Lab # 579561
Collected By/Date TUCKER SC 11/9/2021

Report Date 01-Dec-21

Analyte	Result	Units	LOD	LOQ	Dil	Dig Date	Run Date	Mthd	Analyst	QC Code
Zinc	17.4	ug/l	7	23.2	1		12/1/2021	200.7	NMP	1

(as total Zn)...Zinc is used in a number of alloys such as brass and bronze, and in batteries, fungicides, and pigments. Zinc is an essential growth element for plants and animals but at elevated levels it is toxic to some species of aquatic life. The EPA secondary drinking water maximum contaminant limit is 5000 ug/L. Concentrations above 5000 ug/L can cause a bitter taste.

Organic

Coliform and E-coli Bacteria

Coliform	None Detected	mpn	1	1	1		11/11/2021	9223B	JM	1
----------	---------------	-----	---	---	---	--	------------	-------	----	---

COLIFORM BACTERIA...Coliform bacteria are very common in the open environment. They can be found in the soil and in surface water. However, any detection of coliform bacteria colonies in drinking water is unnatural.

RESULT - Coliform bacteria were ABSENT in this sample. No Coliform bacteria were found in this sample. NOTE: The absence of bacteria does not necessarily mean that other pollutants are not present in the water. If you are concerned about other contaminants, further testing will be necessary.

E-coli	None Detected	mpn	1	1	1		11/11/2021	9223B	JM	1
--------	---------------	-----	---	---	---	--	------------	-------	----	---

E-COLI BACTERIA - Found in human and animal waste. The presence of E-coli is an indication of septic contamination, barnyard runoff, or another direct source of waste entering the drinking water system.

RESULT- ABSENT - No E-coli bacteria were detected in this sample.

LOD Limit of Detection

None Detected = Result was less than the LOD

LOQ Limit of Quantitation

Code

Comment

1

All laboratory QC requirements were met for this sample.

Laboratory Director

Please visit our website at www.cleanwatertesting.com

WI DNR Lab Certification # 445126660

EPA ID# W100063

WI Dept of Ag Lab ID # 152673-D3

Page 5 of 5

DUNTLEY WATER WORKS LLC

W5844 GEHLER ROAD
JEFFERSON, WI 53549
920-689-8474
1% AFTER 30 DAYS

Customer's Order No. _____		Date <u>Nov. 4</u> 20 <u>21</u>	
Name <u>Tucker Schuett</u>			
Address <u>N-7097 Nielsen Ln</u> <u>Johnson Creek, WI 53038</u>			
Phone: <u>920-650-3153</u>			
SOLD BY <u>KS</u>	CASH	C.O.D.	CHARGE
ON ACCT.	MDSE. RETD.	PAID OUT	
QUAN.	DESCRIPTION	PRICE	AMOUNT
1	1/2hp 3-wire Sta-Rite Pump	\$ 700.00	
1	1/2hp Sta-Rite Control Box	\$ 282.57	
58'	#12-3 Flat Blue Pump Wire	\$ 60.05	
1	1" Midwest Check Valve	\$ 68.00	
1	1" PVC Coupling	\$ 4.00	
2	Cable Grounds	\$ 6.00	
1	Splice Kit	\$ 18.00	
1 1/2 hrs	Labor for 2 men	\$ 180.00	
1	Service Charge	\$ 75.00	
All claims and returned goods MUST be accompanied by this bill.		TAX	
		TOTAL	\$ 1,393.62
Received By _____			

Thanks Russ
and Kyle

WELLS-SEPTIC-PUMPING

Service and Installation • Soil Testing
Well and Septic Inspections • 24 Hour Emergency Service
 (608) 837-5297 • Eckmayer Sewer Service
 (920) 563-2988 • Fort Septic Service
 (920) 478-2379 • Tesmer Plumbing

Fax (920) 478-3138 • www.eckmayerinc.com • N8458 County Rd. 0 • Waterloo, WI 53594

NAME Madeline Schmitt

ADDRESS N 7047 Nielson Ln

Phasen creek

SOLD BY	CASH	CHARGE	TRUCK	CODE	FIELD
7H			32	5	1001
					Amount

Quantity	Description		
	Septic/Holding/Pump Chamber/Combo Pumping		
	Gallons <u>1000</u>		
	Tank Level <u>on</u> Ponding <u>correct</u> (waste hole)		
	Baffles <u>on</u> Filter <u>new</u>		
	Locking device <u>(Y)</u> / N		
	Vermin Proof Well Cap <u>(Y)</u> / N	185	00
	Suggest 6x20 in. x 20 in. check valves		
	P450 check #		
	1143		

1.5% interest on all accounts 30 days past due.

RECEIVED BY

TAX

TOTAL

185	cc
-----	---------------

770180

All claims and returned goods
MUST be accompanied by this bill.

THANK YOU

BP 25871-08/08
Rail No. Q 2602006

Eckmayer Inc.
N8458 CTH O
Waterloo, WI 53594

Phone: (608) 837-5297
Fax: (920) 478-3138
www.eckmayerinc.com
eckmayer@frontier.com

Invoice

56967

Issue Date 10/31/22
Terms 30 Days
Due Date 11/29/22

Madeline Schuett
N7097 Nielson Lane
Johnson Creek, WI 53038

Emailed	PO Number
---------	-----------

Charge Name	Description	Charge
Work Order: 56967-1, Date: 10/27/22, Service Location: N7097 Nielson Lane, Johnson Creek, WI 53038		
Service Call		\$125.00
Riser 6" x 20"		\$100.00

Subtotal \$225.00
Discount -\$30.00
Tax \$0.00
Paid \$0.00

Balance Due \$195.00

AS REQUIRED BY THE WISCONSIN CONSTRUCTION LIEN LAW, CLAIMANT HEREBY NOTIFIES OWNER THAT PERSONS OR COMPANIES PERFORMING, FURNISHING, OR PROCURING LABOR, SERVICES, MATERIALS, PLANS, OR SPECIFICATIONS FOR THE CONSTRUCTION ON OWNER'S LAND MAY HAVE LIEN RIGHTS ON OWNER'S LAND AND BUILDINGS IF NOT PAID. THOSE ENTITLED TO LIEN RIGHTS, IN ADDITION TO THE UNDERSIGNED CLAIMANT, ARE THOSE WHO CONTRACT DIRECTLY WITH THE OWNER OR THOSE WHO GIVE THE OWNER NOTICE WITHIN 60 DAYS AFTER THEY FIRST PERFORM, FURNISH, OR PROCURE LABOR, SERVICES, MATERIALS, PLANS OR SPECIFICATIONS FOR THE CONSTRUCTION. ACCORDINGLY, OWNER PROBABLY WILL RECEIVE NOTICES FROM THOSE WHO PERFORM, FURNISH, OR PROCURE LABOR, SERVICES, MATERIALS, PLANS, OR SPECIFICATIONS FOR THE CONSTRUCTION, AND SHOULD GIVE A COPY OF EACH NOTICE RECEIVED TO THE MORTGAGE LENDER, IF ANY. CLAIMANT AGREES TO COOPERATE WITH THE OWNER AND OWNER'S LENDER, IF ANY, TO SEE THAT ALL POTENTIAL LIEN CLAIMANTS ARE DULY PAID.

All invoices are due within 30 days of the invoice billing date. A late charge of 1% per month will be assessed on all past due accounts. In addition, you will be charged for all attorney's fees and court costs incurred by us in collecting your balance.

ANY INVOICE \$1,000 OR MORE THAT IS PAID WITH A CREDIT/DEBIT CARD WILL INCUR A 2% CONVENIENCE FEE