Well Construction Report
WISCONSIN UNIQUE WELL NUMBER UB542

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MARCO, PETE			Phone #
Mailing Address: N7815 CO HWY W			
City: HOLMEN	State: WI	Zip Code: 54636	
County: La Crosse	Co. Permit #: 27080	Notification #: 26314189	Completed: 06-15-2007

Well Constructor (Business Name): MEDARY DRILLING CO	Lic. #: 6703	Facility ID # (Public Wells)	
Address: 624 AMY DR HOLMEN WI 54636		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.8	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of FARMINGTON

Fire # (if avail.): N7815

Street Address or Road Name and Number: CO HWY W

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.0037 °N	-91.157 °W			GCD013
NW SE or Govt Lot #	Section: 25	Township: 18 N	Range: 7 W	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
WATER SUPPLY

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	83
6	83	140

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Yes / Yes — Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 10depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	10
-	-	N	-	SANDSTONE	10	75
-	-	H	-	SHALE	75	110
-	-	N	-	SANDSTONE	110	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM-A53 P.E. 280 WALL 18.97#/FT WHEATLAND PIPE	Surface	83
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	83	17 S

9. Static Water Level
42 ft. below ground surface

10. Pump Test
Pumping level 66 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RCS		07-06-2007
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
SH		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		200
Building Drain - Sanitary		40

Type	Qualifier	Distance
Building Overhang		25
Sewer - Building Sanitary		40
Septic or Holding, or POWTS Tank		150

Comment:

Created On: 11-13-2007 Updated On: 04-30-2020 Review Status: