



4/7/26

2304 Thor Avenue
Racine, WI 53405

I have inspected the basement at 2304 Thor Avenue, Racine, WI. I find the walls to be straight and sound with no issue in the construction of the walls. As they observed the exterior of the home, I saw the down spouts needed to be extended from the house, which would cause water issues in the basement.

Anthony D'Alie
D'Alie Masonry