Insulation Certificate

The following information is based on intallation per manufacturer's specifications.

Address: 240 E North St Whitewater, WI

Location Installed	Insulation Type	Coverage Area Square Feet	Thickness Inches	R-Value* Installed	Number of Bags Used**	Min. Settled Thickness**	Final/Total R-Value**
Attic						** Complete where applicable.	
	Cellulose	394	14	R-50	30	14"	R-50
	Slopes	258	10	R-30	20	10"	R-30
Sidewalls							
	Cellulose	691	3.5	R-13	35	3.5	R-13
Floors							
Foundation							
Sill Box							
Other							
	Crew space	280	Poly	1 roll	6mil		

*** Note:** R-Value is a measure of insulating power.

Weatherization Agency Name: Weatherization Services

Signature of Representative: Devin Hawthorne

Date: 01/12/21