

Certificate of Analysis

WO#: 2607E93

Date Reported: 7/20/2026

CLIENT: Mich-Inspect
Attn: Mr. Charles West
LAB ID: 2607E93-01
Client Sample ID 2484 Shadow Lake Ct.
Project: 2484 Shadow Lake Ct.
Sample Location: Kitchen

Collection Date: 7/17/2026 9:45:00 AM
Received Date: 7/17/2026 9:55:00 AM
Matrix: Drinking Water
Sampled By: KM

Test	Result	RL	Qual	Units	MCL	Analysis Date
COLIFORM BY PRESENCE-ABSENCE			By Method: SM 9223B			Analyst: AS
E. coli	Absent			P/A		7/17/2026 2:15:00 PM
Coliform, Total	Absent			P/A		7/17/2026 2:15:00 PM
NITRATE, DRINKING WATER			By Method: EPA 300.0			Analyst: KA
Nitrite	< 0.100	0.100		mg/L	1.00	7/17/2026 10:42:00 AM
Nitrate	< 0.100	0.100		mg/L	10.0	7/17/2026 10:42:00 AM

Comments:

The data and information presented herein, while not guaranteed, are to the best of our knowledge accurate and true. No warranty or guarantee implied or expressed is made regarding these analytical results, since securing and properly preserving representative samples and since sample custody chains are beyond lab's control. Alteration or reproduction other than in its entirety is not authorized

Qualifiers: < Not Detected at the Reporting Limit
MCL Maximum Contaminant Level
RL Reporting Limit

H Holding times for preparation or analysis exceeded
PL Permit Limit

Approved By: 
Steve Bylsma
Laboratory Manager